

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N | Y | I | P | S | 3 | 2 | 0 | - | 0 | 0 | 0 | 0 | 0 | + | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 8 | 6 | 7 | 1 | 1 | 2 | 7 | 7 | 9 | 8 | 1 | 1 | 2 | 8 | 7 | 9 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | WHILE SHUT DOWN FOR REFUELING, ANALYSIS OF ACCUMULATOR LEVEL CALIBRATION
03 | TEST, 3PC-R16, SHOWED ACCUMULATOR 31 AND 34 LEVEL TRANSMITTERS TO BE OUT
04 | OF SPECIFICATION. THIS MAY HAVE ALLOWED OPERATION WITH 31 AND 34
05 | ACCUMULATOR LEVELS BELOW THE DESIGNATED MINIMUM BY 23.6 CUBIC FEET AND
06 | 10.5 CUBIC FEET RESPECTIVELY. TECHNICAL SPECIFICATION 3.3.A.3.C.
07 | REQUIRES A MINIMUM OF 800 CUBIC FEET OF WATER IN EACH ACCUMULATOR TANK.

08 | _____
09 | SYSTEM CODE: C J 11 | CAUSE CODE: E 12 | CAUSE SUBCODE: E 13 | COMPONENT CODE: I N S T R U 14 | COMP. SUBCODE: I 15 | VALVE SUBCODE: Z 16
17 | LER/RO REPORT NUMBER: 7 9 | SEQUENTIAL REPORT NO.: 0 1 1 5 | OCCURRENCE CODE: 0 | REPORT TYPE: T | REVISION NO.: 0
ACTION TAKEN: E 18 | FUTURE ACTION: Z 19 | EFFECT ON PLANT: Z 20 | SHUTDOWN METHOD: Z 21 | HOURS: 0 0 0 0 | ATTACHMENT SUBMITTED: N 23 | NPRD-4 FORM SUB.: N 24 | PRIME COMP. SUPPLIER: N 25 | COMPONENT MANUFACTURER: R 3 1 6 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | FOR ACCUMULATORS 31 AND 34, A ROSEMOUNT MODEL 1151, DP LEVEL TRANSMITTER
11 | WAS FOUND TO BE OUTSIDE THE REQUIRED TOLERANCE AND WAS RECALIBRATED. A
12 | SIMILAR EVENT OCCURRED ON JULY 5, 1978. (LER 78-015/03L-0)
13 | _____
14 | _____

15 | FACILITY STATUS: H 28 | % POWER: 0 0 0 0 29 | OTHER STATUS: NA 30 | METHOD OF DISCOVERY: B 31 | DISCOVERY DESCRIPTION: SURVEILLANCE TEST 32
16 | ACTIVITY CONTENT RELEASED OF RELEASE: Z 33 | AMOUNT OF ACTIVITY: Z 34 | NA 35 | LOCATION OF RELEASE: NA 36

17 | PERSONNEL EXPOSURES NUMBER: 0 0 0 37 | TYPE: Z 38 | DESCRIPTION: NA 39

18 | PERSONNEL INJURIES NUMBER: 0 0 0 40 | DESCRIPTION: NA 41

19 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z 42 | DESCRIPTION: NA 43

20 | ISSUED DESCRIPTION: N 44 | NA 45
7912040369
NRC USE ONLY
NAME OF PREPARER: FLOYD W. GUMBLE
PHONE: 914-739-8200, X217