LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | ● | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Entry
01	LICENSEE CODE (2)	N Y I P S 3
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
CON'T 01	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 2 8 6
	EVENT DATE (8)	1 1 2 7 7 P
	REPORT DATE (9)	1 2 0 7 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 WHILE SHUT DOWN FOR REFUELING, THE POWER AUTHORITY WAS NOTIFIED BY OUR
03 NSSS, THE WESTINGHOUSE ELECTRIC CORPORATION, THAT A DETAILED EVALUATION
04 OF THE CURRENT LOCA/ECCS EVALUATION MODEL (OCTOBER 1975) INDICATES THAT
05 A NON-CONSERVATIVE FEATURE COULD EXIST IN THE APPENDIX K LOCA ANALYSIS
06 WITH RESPECT TO THE PORTION OF THE CALCULATIONS RELATED TO FUEL BURST.
07 NO SIMILAR EVENTS HAVE OCCURRED TO DATE.
08

09	SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
	R C	B	A	Z Z Z Z Z Z	Z	Z

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
7 9	—	0 1 6	/	0 1	T	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
X	Z	Z	Z	0 0 0 0	Y	N	N	Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE WESTINGHOUSE ANALYSIS IS CONCERNED WITH HEATUP RATES LESS THAN 25
11 DEGREES FARENHEIT PER SECOND, BELOW WHICH THE POTENTIAL FOR FUEL BURST
12 IS GREATER. WESTINGHOUSE HAS DETERMINED THAT THE POSSIBILITY FOR TEMPER-
13 ATURE INCREASE BELOW THIS RATE EXISTS, AND AN ANALYSIS IS PRESENTLY
14 UNDERWAY TO ENSURE THAT THE SYSTEM IS NOT ADVERSELY AFFECTED BY THIS.

15	FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
	H	0 0 0	NA	D	NSSS NOTIFICATION

16	ACTIVITY RELEASED (33)	CONTENT OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z	Z	NA	NA

PERSONNEL EXPOSURES

17	NUMBER (37)	TYPE (38)	DESCRIPTION (39)
	0 0 0	Z	NA

PERSONNEL INJURIES

18	NUMBER (40)	DESCRIPTION (41)
	0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY (43)

19	TYPE (42)	DESCRIPTION
	Z	NA

333

PUBLICITY

20	ISSUED (44)	DESCRIPTION (45)
	N	NA

7912110333

NRC USE ONLY

NAME OF PREPARER: FLOYD W. GUMBLE

PHONE: 914-739-8200,X217

GPO 917-926