(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE (2)	N Y I P S 3
	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
	LICENSE TYPE (4)	4 1 1 1 1
	CAT (5)	
CON'T 0 1	REPORT SOURCE (6)	L
	DOCKET NUMBER (7)	0 5 0 0 0 2 8 6
	EVENT DATE (8)	1 1 2 7 7 9
	REPORT DATE (9)	1 2 1 4 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 WHILE SHUT DOWN FOR REFUELING, THE POWER AUTHORITY WAS NOTIFIED BY OUR
0 3 NSSS, THE WESTINGHOUSE ELECTRIC CORPORATION, THAT A DETAILED EVALUATION
0 4 OF THE CURRENT LOCA/ECCS EVALUATION MODEL (OCTOBER 1975) INDICATES THAT
0 5 A NON-CONSERVATIVE FEATURE COULD EXIST IN THE APPENDIX K LOCA ANALYSIS
0 6 WITH RESPECT TO THE PORTION OF THE CALCULATIONS RELATED TO FUEL BURST.
0 7 NO SIMILAR EVENTS HAVE OCCURRED TO DATE.
0 8

0 9	SYSTEM CODE (11)	R C
	CAUSE CODE (12)	B
	CAUSE SUBCODE (13)	A
	COMPONENT CODE (14)	Z Z Z Z Z Z
	COMP. SUBCODE (15)	Z
	VALVE SUBCODE (16)	Z
(17) LER/RO REPORT NUMBER	EVENT YEAR	7 9
	SEQUENTIAL REPORT NO.	0 1 6
	OCCURRENCE CODE	0 1
	REPORT TYPE	T
	REVISION NO.	1
	ACTION TAKEN (18)	X
	FUTURE ACTION (19)	Z
	EFFECT ON PLANT (20)	Z
	SHUTDOWN METHOD (21)	Z
	HOURS (22)	0 0 0 0
	ATTACHMENT SUBMITTED (23)	Y
	NPRD-4 FORM SUB. (24)	N
	PRIME COMP. SUPPLIER (25)	N
	COMPONENT MANUFACTURER (26)	Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE WESTINGHOUSE ANALYSIS IS CONCERNED WITH HEATUP RATES LESS THAN 25
1 1 DEGREES FARENHEIT PER SECOND, BELOW WHICH THE POTENTIAL FOR FUEL BURST
1 2 IS GREATER. WESTINGHOUSE HAS DETERMINED THAT THE POSSIBILITY FOR TEMPER-
1 3 ATURE INCREASE BELOW THIS RATE EXISTS, AND AN ANALYSIS IS PRESENTLY
1 4 UNDERWAY TO ENSURE THAT THE SYSTEM IS NOT ADVERSELY AFFECTED BY THIS.

1 5	FACILITY STATUS (28)	H
	% POWER (29)	0 0 0
	OTHER STATUS (30)	NA
	METHOD OF DISCOVERY (31)	D
	DISCOVERY DESCRIPTION (32)	NSSS NOTIFICATION
1 6	ACTIVITY RELEASED (33)	Z
	CONTENT OF RELEASE (34)	Z
	AMOUNT OF ACTIVITY (35)	NA
	LOCATION OF RELEASE (36)	NA
1 7	PERSONNEL EXPOSURES NUMBER (37)	0 0 0
	TYPE (38)	Z
	DESCRIPTION (39)	NA
1 8	PERSONNEL INJURIES NUMBER (40)	0 0 0
	DESCRIPTION (41)	NA
1 9	LOSS OF OR DAMAGE TO FACILITY TYPE (42)	Z
	DESCRIPTION (43)	NA
2 0	PUBLICITY ISSUED (44)	N
	DESCRIPTION (45)	NA

7912180582

NRC USE ONLY

NAME OF PREPARER FLOYD W. GUMBLE PHONE: 914-739-8200, X217

GPO 917-926