


LICENSEE EVENT REPORT

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	I	P	S	3	2	0	0	-	0	0	0	0	0	0	1	0	0	3	4	1	1	1	1	4			5
7	8	14						15	25										26	30					57	CAT	58			
		LICENSEE CODE							LICENSE NUMBER											LICENSE TYPE										

CON'T

REPORT SOURCE 0 1 7 8 L 6 0 5 0 0 0 2 8 6 7 1 1 2 7 7 9 8 1 2 1 4 7 9 9 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 WHILE SHUT DOWN FOR REFUELING, THE POWER AUTHORITY WAS NOTIFIED BY OUR
03 NSSS, THE WESTINGHOUSE ELECTRIC CORPORATION, THAT A DETAILED EVALUATION
04 OF THE CURRENT LOCA/ECCS EVALUATION MODEL (OCTOBER 1975) INDICATES THAT
05 A NON-CONSERVATIVE FEATURE COULD EXIST IN THE APPENDIX K LOCA ANALYSIS
06 WITH RESPECT TO THE PORTION OF THE CALCULATIONS RELATED TO FUEL BURST.
07 NO SIMILAR EVENTS HAVE OCCURRED TO DATE.

0 8 | _____ 8

SYSTEM CODE [0] [9]		CAUSE CODE [B]		CAUSE SUBCODE [A]		COMPONENT CODE [Z] [Z] [Z] [Z] [Z] [Z]				COMP. SUBCODE [Z]		VALVE SUBCODE [Z]					
EVENT YEAR [7] [9]		SEQUENTIAL REPORT NO. [0] [1] [6]		OCCURRENCE CODE [0]		REPORT TYPE [I]		REVISION NO. [1]									
ACTION TAKEN [X]		FUTURE ACTION [Z]		EFFECT ON PLANT [Z]		SHUTDOWN METHOD [Z]		HOURS [0] [0] [0] [0]		ATTACHMENT SUBMITTED [Y]		NPRD-4 FORM SUB. [N]		PRIME COMP. SUPPLIER [N]		COMPONENT MANUFACTURER [Z] [9] [9] [9]	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE WESTINGHOUSE ANALYSIS IS CONCERNED WITH HEATUP RATES LESS THAN 25
1 1 DEGREES FARENHEIT PER SECOND, BELOW WHICH THE POTENTIAL FOR FUEL BURST
1 2 IS GREATER. WESTINGHOUSE HAS DETERMINED THAT THE POSSIBILITY FOR TEMPER-
1 3 ATURE INCREASE BELOW THIS RATE EXISTS, AND AN ANALYSIS IS PRESENTLY
1 4 UNDERWAY TO ENSURE THAT THE SYSTEM IS NOT ADVERSELY AFFECTED BY THIS.

	7	8	9	FACILITY STATUS	% POWER	OTHER STATUS	(30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION	(32)		
	1	5	H	(28)	10 11 12 13 NA			D	NSSS NOTIFICATION			
	7	8	9		10	11	12	13	44	45	46	80

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)

1 6 7 33 7 34 NA

7 9 9 10 11 44

LOCATION OF RELEASE (36)

NA

45 80

PERSONNEL EXPOSURES			
NUMBER		TYPE	DESCRIPTION
1	7	(37) Z	(38) NA

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1 8	0 0 0	(40)	NA

7		8	9	11	12	
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION		(43)
1	9	Z	(42)	NA		

7 8 9 10
PUBLICITY
ISSUED IN DESCRIPTION (45)
2 3 4 5 6 7 8 9 10
7912180 582
NRC USE ONLY

[illegible]

10
NAME OF PREPARER FLOYD W. GUMBLE

PHONE: 914-739-8200, x217

7912180 582

NRC USE ONLY

017-926