

# LICENSEE EVENT REPORT

CONTROL BLOCK:            ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | Y | I | P | S | 3 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 |     | 5  
7 8 9                    14 15                    25 26                    57 CAT 58

CON'T  
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 8 | 6 | 7 | 1 | 2 | 0 | 2 | 7 | 9 | 8 | 1 | 2 | 2 | 8 | 7 | 9 | 9  
7 8                    60 61                    DOCKET NUMBER                    68 69                    EVENT DATE                    74 75                    REPORT DATE                    80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

0 2 | WHILE SHUT DOWN FOR REFUELING, HYDROGEN RECOMBINER TEST, 3PT-R12  
0 3 | INDICATED AN EXCESSIVE DILUENT TEMPERATURE (APPROXIMATELY 100 DEGREES  
0 4 | ABOVE THE OPERATING LIMIT OF 300 DEGREES FARENHEIT) ON RECOMBINER NO.  
0 5 | 32, DEGRADING THE OPERABILITY OF ONE OF THE HYDROGEN RECOMBINERS  
0 6 | REQUIRED BY TECHNICAL SPECIFICATION 3.3.G.1. AS THE PLANT WAS SHUT DOWN,  
0 7 | NO IMMEDIATE ACTION WAS REQUIRED. NO SIMILAR EVENTS HAVE BEEN REPORTED  
0 8 | TO DATE.

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE  
S | E | 11 | E | 12 | B | 13 | R | E | C | O | M | B | 14 | Z | 15 | Z | 16  
9 10 11 12 13 18 19 20

17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.  
7 | 9 | 7 | 9 | 0 | 1 | 4 | 0 | 3 | L | 0  
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER  
E | 18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | N | 23 | N | 24 | N | 25 | W | 1 | 2 | 0 | 26  
33 34 35 36 37 40 41 42 43 44 47

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ⑳

1 0 | A MISALIGNED LOUVER ON WESTINGHOUSE HYDROGEN RECOMBINER NO. 32 (MODEL  
1 1 | NO. 2518B) WAS REPOSITIONED, AND DILUENT TEMPERATURE RETURNED TO  
1 2 | ACCEPTABLE VALUE. POSITIVE MEANS ARE PRESENTLY BEING IMPLEMENTED TO  
1 3 | SECURE THE LOUVER SO TO PREVENT FUTURE EVENTS OF THIS TYPE.

1 4 | FACILITY STATUS | % POWER | OTHER STATUS ⑳ | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION ㉓  
H | 28 | 0 | 0 | 0 | 0 | 29 | NA | A | 31 | SURVEILLANCE TEST  
7 8 9 10 12 13 44 45 46 80

1 5 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY ㉕ | LOCATION OF RELEASE ㉖  
Z | 33 | Z | 34 | NA | NA  
7 8 9 10 11 44 45 80

1 6 | PERSONNEL EXPOSURES | DESCRIPTION ㉙  
0 | 0 | 0 | 37 | Z | 38 | NA  
7 8 9 11 12 13 80

1 7 | PERSONNEL INJURIES | DESCRIPTION ㉛  
0 | 0 | 0 | 40 | NA  
7 8 9 11 12 80

1 8 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION ㉝  
0 | 0 | 0 | 42 | NA  
7 8 9 11 12 80

1 9 | PUBLICITY ISSUED | DESCRIPTION ㉞  
N | 44 | NA  
7 8 9 10 80

8001020 364