

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NY 1 P S 3 20 0 0 - 0 0 0 0 0 0 + 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 REPORT SOURCE L 6 0 5 0 0 0 2 8 6 7 1 2 1 0 7 9 8 0 1 0 9 8 0 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 WHILE SHUT DOWN FOR REFUELING, PERFORMANCE OF 3PC-R10 REFUELING WATER
03 STORAGE TANK LEVEL CALIBRATION TEST INDICATED THAT THE LOW LEVEL LIMIT
04 ON THE BARTON DP AUXILIARY-LEVEL ALARM WAS SET AT 73,100 GALLONS, WHICH
05 IS LESS CONSERVATIVE THAN THE MINIMUM ACCEPTABLE LOW LEVEL ALARM LIMIT
06 OF 98,100 GALLONS, ACCORDING TO TECHNICAL SPECIFICATION 3.3.A.1.B. THE
07 REDUNDANT LOW LEVEL ALARM WAS FOUND TO BE OPERABLE WITHIN THE ALLOWED
08 RANGE.

09 SYSTEM CODE WIG 11 CAUSE CODE E 12 CAUSE SUBCODE E 13 COMPONENT CODE INSTRU 14 COMP. SUBCODE X 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 LER/RO REPORT NUMBER 7 9 21 EVENT YEAR 22 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER B O 8 0 26
23 24 25 26 27 28 29 30 31 32
ACTION TAKEN E 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER B O 8 0 26
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 AS THE REACTOR COOLANT WAS BELOW 350 DEGREES FARENHEIT AT THE TIME, NO
11 IMMEDIATE ACTION WAS REQUIRED. THE BARTON MODEL 288 DP LOW LEVEL INDI-
12 CATOR WAS RECALIBRATED. THE CAUSE OF THIS INCIDENT WAS DETERMINED TO BE
13 INSTRUMENT DRIFT. A SIMILAR EVENT WAS REPORTED ON AUGUST 20, 1978 (LER 79-
14 -018/03L-0).

15 FACILITY STATUS H 28 % POWER 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION: PROCEDURE REVIEW 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

16 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

8001150631

NRC USE ONLY

NAME OF PREPARER FLOYD W. GUMBLE

PHONE: 914-739-8200, X217

GPO 617-926