

## POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

## TRUSTEES

JOHN S. DYSON  
CHAIRMANGEORGE L. INGALLS  
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

FREDERICK R. CLARK

December 28, 1979  
IPN-79-103GEORGE T. BERRY  
PRESIDENT & CHIEF  
OPERATING OFFICERJOHN W. BOSTON  
EXECUTIVE VICE  
PRESIDENT & DIRECTOR  
OF POWER OPERATIONSJOSEPH R. SCHMIEDER  
EXECUTIVE VICE  
PRESIDENT & CHIEF  
ENGINEERLEROY W. SINCLAIR  
SENIOR VICE PRESIDENT  
& CHIEF FINANCIAL  
OFFICERTHOMAS R. FREY  
SENIOR VICE PRESIDENT  
& GENERAL COUNSEL

Mr. Boyce H. Grier, Director  
Office of Inspection and Enforcement  
Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pa. 19406

Subject: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
Response to NRC I.E. Bulletin 79-02  
Revision 2, Item 1

Dear Mr. Grier:

The purpose of this letter is to inform the Commission that the Authority has completed Item 1 of I.E. Bulletin 79-02, Rev. 2 in accordance with the schedule provided in our letter dated December 7, 1979.

The Item 1 anchor bolt loads, for pipe support base plates, were recalculated in accordance with the methodology described in attachment 1 to our July 6, 1979 letter to the Commission.

Very truly yours,



Paul J. Early  
Assistant Chief Engineer-Projects

8002110

515

A02