September 20, 1968

File

CONSOLIDATED EDISON CO. OF N. Y., INDIAN POINT #3, Docket No. 50-286

Pursuant to an oral request (9/16/68) from RPB #1 (J. Murphy), the subject PSAR was reviewed regarding operational aspects contained within the application. It was revealed that both conduct of operations and initial tests and operation have been completely omitted from the application.

Based upon the above it has been concluded that the PSAR is incomplete and until the required information is submitted by the applicant our review can not be completed. RPB #1 has been advised.

It should be noted that the current RP review schedule anticipates preparation of the staff report to the ACRS in November with an ACRS review in December.

Ralph A. Birkel Operational Safety Branch, DRL

8111200482 680920 ADDCK 05000286

OFFICE ▶	OSB:DRL			
	160			
and the second s	RABirkel:cl		 -	
DATE >	9/20/68	 	 	<u></u>

J. R. Buchanan
Assistant Director
Nuclear Safety
Information Center
Oak Ridge Nat'1 Lab.

P. O. Box Y
Oak Ridge, Tennessee
37831

Original signed by
Nan M.Blunt
Roger S. Boyd
Asst. Director for
Reactor Projects
Division of Reactor
Licensing, BETH-010

7441 9/11/68

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.
(Indian Point Nuclear Generating Unit 3)
Docket No. 50-286

The following document is attached for your information:

First Supplement (Amendment No. 1) dated August 30, 1968, to facility license application filed by the above Company for the Indian Point Nuclear Generating Unit 3 in answer to the Commission's requests of February 19 and July 1, 1968.

Identical route slips sent to Case, Giambusso, Pressesky, Forbes, and Lauthlin.

Distribution: WHH
Suppl.

RL Reading
RPB-1 Reading
R. S. Boyd
N. M. Blunt

OFFICE ▶	RL:RPB-1			
017.02				
SURNAME ▶	NMB1unt:brm	 		
DATE	9/11/68		 	