

R. Boyd
Steel

Controller

Original signed by
A. Giambusso

JUN 26 1967

**A. Giambusso, Assistant Director
for Project Management
Division of Reactor Development & Technology
FACILITY LICENSE APPLICATION FILED BY CONSOLIDATED EDISON COMPANY OF
NEW YORK, INC., INDIAN POINT STATION UNIT NO. 3, DOCKET NO. 50-286**

RDT:PM:W223

As requested in Roger S. Boyd's memorandum dated May 17, 1967, we have reviewed the reasonableness of the special nuclear fuel requirement for the first core of this reactor. The quantity of 218,530 lbs. of UO₂ in the core, as listed on page 2-15, Table 2-1, in subject's Preliminary Safety Analysis Report is a reasonable amount for a reactor of this size and power level.

cc: Director, DRL
R. S. Boyd, Asst. Dir., DRL
C. A. Lovejoy, OS

8111200751 670626
ADOCK 05000286