

JAN 21 1975

247 - 286

D. Vassallo, Chief, LWR Branch, 1-1, L

INDIAN POINT 3 SPRAY SYSTEM

Our review of Amendment No. 28 of the Indian Point Unit 3 application brought to light an item which we would like to bring to your attention: the spray additive portion of the containment spray system incorporates a timer to delay sodium hydroxide addition following a spray actuation signal. However, current technical specifications for operating plants require the spray additive function of the spray system to be available upon system actuation (i.e., without delay). We request that you bring this requirement to the applicant's attention in order to avoid difficulties in the implementation of the technical specifications at a later time.

Our SER dose calculations were performed assuming immediate spray and filter effectiveness.

This review was performed by W. Pasedag, AAB.

1/8

Brian K. Grimes, Chief  
Accident Analysis Branch  
Directorate of Licensing

cc: S. Hanauer  
F. Schroeder  
R. Boyd  
TR A/D's  
TR T/C's  
SS B/C's  
C. Ferrell  
M. Aycock  
W. Pasedag

Distribution:  
✓ Central Files  
AD/SS/L  
L:Reading  
AAB:Reading

memo  
4

8111200063 750121  
ADOCK 05000247

OFFICE >	AAB:LP	AAB:L			
SURNAME >	WPasedag/dr	BC/imes			
DATE >	1/21/75	1/21/75			