

JUL 25 1973

50-286

D. B. Vassallo, Chief, Pressurized Water Reactors Branch No. 1, L

INDIAN POINT-3 ACRS SUBCOMMITTEE MEETING

I have read the July 11, 1973 transcript on the subject meeting and H. Specter's memo of July 17, on the same subject. In addition to Herschel's comments, I believe we should be ready to state staff positions on:

1. Basis for peaking factor (p. 19)
2. Steam generator tube reliability experience (p. 22, 23)
3. Calculations on containment leak as it affects ECCS (p. 31)
4. Incore requirements (p. 32)
5. PL rod positions (p. 32)
6. Independent checking of peaking factor (p. 37)
7. Flow effect on power distribution (p. 39)
8. Power level to start LOCA analysis (p. 80)
9. Pump overspeed (p. 166)

I suggest we meet soon to discuss TR:RS participation for the next subcommittee meeting.

151

D. F. Ross, Chief
Core Performance Branch
Directorate of Licensing

cc: V. Stello, L:RS
M. Dunenfeld, L:CPB
T. Novak, L:RSB

Distribution:
Docket file ✓
CPB Reading
L Reading (M. Groff)
D. Ross

8111240078 730725
ADOCK 05000286

OFFICE ▶	CPB								
SURNAME ▶	DFRoss;bjn								
DATE ▶	7/ /73								