

NOV 06 1973

Docket, No. 50-286

D. B. Vassallo, Chief, Pressurized Water Reactors Branch No. 1, L
FORTHCOMING INDIAN POINT UNIT 3 FULL ACRS MEETING

DATE: November 9, 1973, Friday

TIME: 11:15 a.m.

LOCATION: Room 1046
1717 H Street
Washington, D. C.

PURPOSE: See attached agenda.

PARTICIPANTS: ACRS - All members
Con. Ed. - W. Cahill et al
AEC - D. Vassallo, H. Specter,
T. Novak et al

Original signed by
H. Specter

H. Specter, Project Manager
Pressurized Water Reactors
Branch No. 1
Directorate of Licensing

cc: Docket	TR Branch Chiefs
AEC PDR	R. W. Klecker
Local PDR	R. F. Fraley, ACRS (16)
L Rdg.	RO (4)
RP Rdg	RP Asst. Directors
PWR-1 Rdg	RP Branch Chiefs
PWR-1 File	Receptionist (H Street)
E. G. Case	T. Novak
A. Giambusso	R. Pollard
J. M. Hendrie	M. Dunenfeld
R. S. Boyd	S. Pawlicki
TR Asst. Directors	F. Allenspach
J. Lee	W. Houston
OCC, S. Treby	H. Specter

MEW

OFFICE ▶	PWR-1				
SURNAME ▶	H. Specter:ms	811240123 731106			
DATE ▶	11/6/73	PDR ADOCK 05000286			
		A			

AGENDA

INDIAN POINT UNIT 3 FULL ACRS MEETING

1. Site Description and Introductory Statement
2. Brief Project Status
3. Core Power Capability Analysis
 - a. Compliance with Interim Acceptance Criteria
 - b. Comparison with Zion and Indian Point 2
 - c. ECCS review and independent analysis
 - d. Sensitivity Analysis (ECCS)
4. Technical Specifications
 - a. Administrative requirements for maintaining peaking factors, e.g., part length rod limitations, rod rate of motion limits
 - b. Core Surveillance Requirements
 - c. Alternative or Additional requirements to account for unanticipated effects, e.g., reductions in F_q to provide for LOCA combined with steam tube rupture
 - d. Peaking Factor Monitoring - Fixed In-Cores vs Other Methods, Use of Thermocouples
 - e. Inservice Inspection (Fracture Toughness) - Inservice Inspection of Steam Generators
5. Emergency Plan/Post Accident Monitoring
 - a. What actions are specified beyond LPZ?
 - b. Instruments provided to follow the course of an accident -
- Discuss adequacy as to instrument range, type of read out, facility of the operator to interpret.
 - c. Does the stack monitor have a high enough range to detect a fuel element failure?
6. Generic Items
 - a. Reactor Coolant Pump Overspeed
 - b. ATWS
 - c. Turbine Overspeed/Missiles
 - d. Failure of Non Class I Components

flooding
electrical cable overheating

isolation of low pressure and high pressure systems

7. Transportation Hazards - Barge Damage

8. Security Plan - Access to site from Hudson River