

bcc: OGC Files - G'tn/Beth
 GBurley
 PHowe
 TConner
 NNewman
 OGC Docket Files

JUL 1 1969

Samuel W. Jensch, Esq., Chairman
 Atomic Safety and Licensing Board
 U. S. Atomic Energy Commission
 Washington, D. C. 20545

Dr. Thomas H. Pigford
 c/o Thermo Electron Corporation
 85 First Avenue
 Waltham, Massachusetts 02154

Dr. John Henry Buck
 Atomic Safety and Licensing Board
 U. S. Atomic Energy Commission
 Washington, D. C. 20545

In the Matter of Consolidated Edison Company of New York, Inc.
 Indian Point Unit No. 3
 Docket No. 50-286

Gentlemen:

In reply to your letter of June 26, 1969, the staff reaffirms the position taken in its Safety Evaluation and at the hearing with respect to the spray removal constant value of 4.9 hr.⁻¹ for inorganic iodine. It is the technical judgment of the staff that this value is adequately conservative and should not be altered. All experimental data presented at the hearing had been previously considered and evaluated by the staff in making its original determination of this spray removal constant.

Sincerely,

FI

Neil J. Newman
 Attorney
 AEC Regulatory Staff

cc: Leonard M. Trosten, Esq.
 Mr. Larry Bogart
 Joseph F. Scinto, Esq.
 Mrs. Mary Hays Weik
 Mr. W. Donham Crawford
 Mr. Stanley T. Robinson, Jr.
 Algie A. Wells, Esq.

8111060629 690701
 PDR ADDCK 05000286
 G PDR

OFFICE	OGC	NEWMAN DRL	DRL	DRL	DRL	DRL
SURNAME	NNewman:ne GFHadlock	GBurley	PHowe	SLevine	RBoyd	PMorris
DATE	6-30-69	6-30-69	6-30-69	6-30-69	6-30-69	6-30-69