



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION I
970 BROAD STREET
NEWARK, NEW JERSEY 07102

J. B. HENDERSON

201 645-3942

Reg. file

March 29, 1971

50-286

J. B. Henderson, Chief, Reactor Construction
Branch, Division of Compliance, HQ

CDN REPLY - CONSOLIDATED EDISON COMPANY, INDIAN POINT 3

The enclosed reply to the Construction Deficiency Notice, dated March 22, 1971, to the subject licensee is forwarded for action in accordance with Provisional Instruction 0700/3, paragraph Fl.e.

The answer is considered inadequate since the licensee's interpretation of Criterion VII 10 CFR 50, which has been restated to say "some documentary evidence", permits acceptance and installation of equipment based on receipt of Quality Release Form from Westinghouse. The proposed documentation does not meet our understanding of the intent of Criterion VII.

for *B M Hunnicutt*
E. M. Howard
Senior Reactor Inspector

Enclosure:
Licensee's reply dated 3/22/71

- cc: J. B. Henderson (3) w/encl ✓
A. Giambusso, CO w/encl
L. Kornblith, Jr., CO w/encl
R. H. Engelken, CO w/encl

8111180059 710329
PDR ADOCK 05000286
G PDR