



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION I
970 BROAD STREET
NEWARK, NEW JERSEY 07102

201 645.

MAR 13 1970

J. P. O'Reilly, Chief, Reactor Inspection & Enforcement Br.,
Division of Compliance, Headquarters.

CONSOLIDATED EDISON COMPANY, INDIAN POINT NO. 3 (IP-3)
DOCKET NO. 50-286.

The attached report of an inspection of the subject facility on
January 27 and 28, 1970, is forwarded for information.

Our inspectors report the Wedco QC organization is currently
functioning and a "rough draft" of the Wedco QA Manual has been
developed. Region I will review this manual when approved by
Con Ed and Westinghouse.

Several important QA-QC procedures which the licensee had previously
informed the inspectors were available on site were in fact not
available. Con Ed management was informed by telephone of our
concern and have promised early action. Followup is planned in
the near future by Region I.

The operation of the substitute concrete batch plant was of concern;
however, the planned return to the primary batch plant (scheduled for
late February) will resolve this problem.

R. T. Carlson

R. T. Carlson
Senior Reactor Inspector

Attachment:

CO Report No. 286/70-2
by R. F. Heishman, dated 3/4/70

cc: E. G. Case, DRS
R. S. Boyd, DRL (2)
S. Levine, DRL (6)
D. J. Skovholt, DRL (3)
L. Kornblith, Jr., CO
Regional Directors, CO
→ REG File

8111180598 700313
PDR ADOCK 05000286
Q PDR