


DK Central Files



UNITED STATES
ATOMIC ENERGY COMMISSION
DIRECTORATE OF REGULATORY OPERATIONS
REGION 1

~~170 BROAD STREET
NEWARK, NEW JERSEY 07102~~

MAR 6 1974

631 Park Avenue
King of Prussia, Pennsylvania 19406

H. D. Thornburg, Chief, Field Support & Enforcement Branch
Directorate of Regulatory Operations, HQ

RO INSPECTION REPORT 50-286/74-02
CONSOLIDATED EDISON COMPANY
LICENSE DPR-26

The subject Inspection report is forwarded for appropriate Headquarters action.

1. Refer to Page 4, paragraph B.1.f of the report. In the licensee's FSAR answer concerning the performance of this test, there was no requirement to conduct the test at $\geq 10\%$ generator output. Regulatory Guide 1.68 is explicit on generator output required prior to the test. Since the licensee remains fast in his position, a resolution is required.
2. Refer to page 4, paragraph B.1.e and page 6, paragraph E of the report. The licensee intends to use a different criteria than that given in Regulatory Guide 1.68 for determining multiple drops of the fastest and slowest rods. The licensee's plan includes a choice from the application of statistics versus an assured ten drops for each of the fastest and slowest rods. Reference Attachment 2, a Con Ed internal memorandum dated November 1, 1973.
3. Refer to page 5, paragraph B.1.g of the report. The test demonstrates shutdown from outside the control room. The licensee does not intend to run an integrated shutdown test and does not meet the criteria given in Regulatory Guide 1.68.

We recommend that DL be advised of the matters discussed in this memorandum and that specific guidance be provided on the tests in question. We request that this guidance be provided by April 19, 1974.

E. J. Brunner
E. J. Brunner

Chief, Reactor Operations Branch

8111110834 740306
PDR ADCK 05000286
Q PDR

Attachments

1. RO Inspection Report No. 50-280/74-02
2. Con Ed Memorandum, November 1, 1973

cc: A. N. Fasano
A. B. Davis

MEMO ROUTE SLIP Form AEC-93 (Rev. May 14, 1947) AECM 0240		See me about this. Note and return.	For concurrence. For signature.	<input checked="" type="checkbox"/> For action. <input checked="" type="checkbox"/> For information.
TO (Name and unit) RO Chief FS&EB RO:HQ (5) RO Files Central Mail & Files Regulatory Standards	INITIALS	REMARKS CONSOLIDATED EDISON CO. IP 3 #50286/74-02		
	DATE			
	(3)			
TO (Name and unit) Directorate of Licensing (13) OGC Regional Directors (II, III, IV)	INITIALS	REMARKS The above inspection report is forwarded for action. Distribution will be made by this office to the PDR, Local PDR, NSIC, DTIE, and		
	DATE			
TO (Name and unit)	INITIALS	REMARKS State Representatives after review by the licensee for proprietary information.		
	DATE			
FROM (Name and unit) <i>E. J. Brunner</i> E. J. Brunner Region I	REMARKS			
PHONE NO. 8-337-1246	DATE 3/6/74			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-469