



NOTES:
 1. CONCRETE FOR REACTOR PIT UP TO EL. 43'-0" SHALL BE OF A COMPRESSIVE STRENGTH OF NOT LESS THAN 4000 P.S.I. IN 28 DAYS.
 2. FOR REFERENCE DRAWINGS SEE F-1126.

P.R.C. APERTURE CARD
POOR ORIGINAL
 TERA APERTURE CARD

NO.	DATE	DESCRIPTION	BY	CHECKED
1	10/1/51	FINAL ISSUE	W.H.	J.P.B.
2	10/1/51	REVISION	W.H.	J.P.B.
3	10/1/51	REVISION	W.H.	J.P.B.
4	10/1/51	REVISION	W.H.	J.P.B.
5	10/1/51	REVISION	W.H.	J.P.B.
6	10/1/51	REVISION	W.H.	J.P.B.
7	10/1/51	REVISION	W.H.	J.P.B.
8	10/1/51	REVISION	W.H.	J.P.B.
9	10/1/51	REVISION	W.H.	J.P.B.
10	10/1/51	REVISION	W.H.	J.P.B.

WESTINGHOUSE ELECTRIC CORPORATION
 CONTAINMENT
 REACTOR PIT
 CONCRETE & REINFORCING DETAILS
 CONSOLIDATED EDISON COMPANY
 INDIAN POINT GENERATING STATION
 UNIT NO. 2
 ENGINEER: W.H. [Signature]
 STATE REG. NO. 10-2213
 9321 F-1175
 8110320630