



Received w/17 dated 6-28-73




| CONTACT | POSITION | |
|---------|----------|-------|
| | 1,2,3 | 4,5,6 |
| A11-B11 | | X |
| A12-B12 | X | |
| A1-B1 | | X |
| A5-B5 | | X |
| A6-B6 | X | |
| A7-B7 | | X |
| C11-D11 | | X |
| C12-D12 | X | |
| C1-D1 | | X |
| C5-D5 | | X |
| C6-D6 | X | |
| C7-D7 | | X |
| E11-F11 | X | |
| E12-F12 | | X |
| E1-F1 | X | |
| E5-F5 | X | |
| E6-F6 | | X |
| E7-F7 | X | |
| G11-H11 | X | |
| G12-H12 | | X |
| G1-H1 | X | |
| G5-H5 | X | |
| G6-H6 | | X |
| G7-H7 | X | |

TYPE "W2"
STYLE 505A629G01
MAINTAINED




| CONTACT | POSITION | |
|---------|----------|----|
| | OFF | ON |
| A11-B11 | | X |
| A12-B12 | X | |
| A1-B1 | | X |
| A5-B5 | | X |
| A6-B6 | X | |
| A7-B7 | | X |
| C11-D11 | | X |
| C12-D12 | X | |
| C1-D1 | | X |
| C5-D5 | | X |
| C6-D6 | X | |
| C7-D7 | | X |
| E11-F11 | | X |
| E12-F12 | X | |
| E1-F1 | | X |
| E5-F5 | | X |
| E6-F6 | X | |
| E7-F7 | | X |
| G11-H11 | | X |
| G12-H12 | X | |
| G1-H1 | | X |
| G5-H5 | | X |
| G6-H6 | X | |
| G7-H7 | | X |

TYPE "W2"
STYLE 505A693G01
MAINTAINED




| CONTACT | POSITION | |
|---------|----------|----|
| | OFF | ON |
| A11-B11 | | X |
| A12-B12 | X | |
| A1-B1 | | X |
| A5-B5 | | X |
| A6-B6 | X | |
| A7-B7 | | X |
| C11-D11 | | X |
| C12-D12 | X | |
| C1-D1 | | X |
| C5-D5 | | X |
| C6-D6 | X | |
| C7-D7 | | X |

TYPE "W2"
STYLE 505A622G01
MAINTAINED



| CONTACT | POSITION | | | |
|---------|----------|---|---|---|
| | 1 | 2 | 3 | 4 |
| A11-B11 | X | | | |
| A12-B12 | | X | | |
| A1-B1 | | | X | |
| A2-B2 | | | | X |
| A3-B3 | X | | | |
| A4-B4 | | X | | |
| A5-B5 | | | X | |
| A6-B6 | | | | X |
| A7-B7 | X | | | |
| A8-B8 | | X | | |
| A9-B9 | | | X | |
| A10-B10 | | | | X |


TYPE "W2" S# 508A343G01
MAINTAINED



| CONTACT | POSITION | | | |
|---------|----------|------|-------|---|
| | STOP | NORM | START | |
| A11-B11 | X | | | |
| A12-B12 | | X | | |
| A1-B1 | | | X | |
| A5-B5 | X | | | |
| A6-B6 | | X | | |
| A7-B7 | | | X | |
| C11-D11 | X | | | |
| C12-D12 | | X | | |
| C1-D1 | | | X | |
| C5-D5 | X | X | | |
| C6-D6 | | X | X | |
| C7-D7 | | | X | X |
| F11-F11 | X | X | | |
| E12-F12 | | X | X | |
| E1-F1 | | | X | X |
| E5-F5 | X | X | | |
| E6-F6 | | X | X | |
| E7-F7 | | | X | X |

TYPE "W2"
STYLE
MAINTAINED

PRC
APERTURE
CARD



| CONTACT | POSITION | | |
|---------|----------|------|--------|
| | DILUTE | AUTO | BORATE |
| A11-B11 | X | | |
| A12-B12 | | X | |
| A1-B1 | | | X |
| A5-B5 | X | | |
| A6-B6 | | X | |
| A7-B7 | | | X |
| C11-D11 | X | | |
| C12-D12 | | X | |
| C1-D1 | | | X |
| C5-D5 | X | | |
| C6-D6 | | X | |
| C7-D7 | | | X |

TYPE "W2"
STYLE S# 505A612G01
MAINTAINED

TERA
APERTURE
CARD

| | | | | |
|---|---|--------------|--|--------------------|
| ECN-6887 WMEARS 12/18/70 1/4/71 1/5/71 | ECN- W. SOLES 10-9-70 1/10/71 10/30/72 | S.O. INT-385 | Westinghouse Electric Corporation | |
| | | | CONSOLIDATED EDISON CO. | |
| TITLE: | | | INDIAN POINT STATION-UNIT NO. 3 | |
| | | | ELEMENTARY WIRING DIAG. | SWITCH DEVELOPMENT |
| | | | M. H. FEECHAK 8-6-69 | 7/1/69 |
| | | | 500B971 | 8/1/69 |
| | | | SHEET-14 | 3/1/62 |
| 3 2 1 SUB | | | ATOMIC POWER DIV., PITTSBURGH, PA., U.S.A. | |

8110230049