



400 CSI- UNIT 17D

- NOTES:
1. WIRE DESIG. PREFIXED WITH 17D
 2. 1/CSI SW. DEV. SH. 9
 3. 2-1/CSI IS A TWO STEP TIMING DEVICE PRE-SET AT FACTORY, LOWER VALVE (LV= 8 SEC) IS SET AT 84% OF UPPER VALVE (UV= 11 SEC.)
 4. SHOP WIRED
5. LETTER (A) ETC. REFERS TO CABLE SCHEMATIC 9321-LL-31173 SH. 32A
6. SI-1X SEE W 113E 303 SH. 6

| | | | | |
|---|--|--|---|----------------------|
| ECN-9678 W.S.D. 3-6-73 J.S. 3-14-73 J.S. 3-14-73 | ECN-8051 J.S. 9-17-71 J.S. 9-17-71 J.S. 9-22-71 | ECN-7161 J.S. 3-8-71 J.S. 3-31-71 J.S. 4-2-71 | ECN-6851-70 J.S. 12-5-70 J.S. 12-8-70 J.S. 12-9-70 | S.O. INT.-385 SUB |
| 5 | 4 | 3 | 2 | 1 |

Westinghouse Electric Corporation

TITLE: CONSOLIDATED EDISON CO.
 INDIAN POINT STATION - UNIT NO. 3

ELEMENTARY WIRING DIAG. CONTAINMENT SPRAY PUMP 31

WM SOLES 9/28/70 J. Lyons 10-27-70

500B971

SHEET- 32

10-30-73

NUCLEAR ENERGY SYSTEMS PITTSBURGH, PA., U.S.A.

8110230064