

6.28-73

VALVE N ^o (MCC LOG.)	FUNCTION	FIG. SH.	SW. SH.	OPER. MODE	INTERLOCKS	REF. DWG. & REMARKS
899A 36B-2FM	RESIDUAL HEAT LOOP DISCHARGE STOP VALVE	9/132 *115A	C/10	Q/FAI		SW-36PANEL IND.LTS.-SBIF 332C ANN SH.160 MON.LT SBIF 33bc "R"LT SH.147
769 36B-3FD	R.C. PUMP CCW SUPPLY ISOLATION VALVE	6/130 *127A	C/10	Q/FAI	769-C2 C-B2IX	SW.-SNF, IND. LTS.-SNF4SGF DWG MON.LT SNF 113E303 SH 6
784 36A-3FH	R.C. PUMP BEARING CCW RETURN ISOLATION VALVE	6/130 *127A	C/10	Q/FAI	784-C2 C-B1IX 784-C	SW.ONSNF PNL. IND.LTS.-SNF4SGF PNL MON.LT SNF 113E303 SH 6
786 36B-3FH	R.C. PUMP BEARING CCW RETURN ISOLATION VALVE	6/130 *127A	C/10	Q/FAI	786-C2 C-B2IX	SW.ONSNF PNL. IND.LTS.-SNF4SGF PNL MON.LT SNF 113E303 SH 6
789 36B-3FM	PUMP THERMAL BARRIER CCW RETURN ISOLATION VALVE	6/130 *127A	C/10	Q/FAI	789-C2 C-B2IX 789-C	SW.ONSNF PNL. IND.LTS.-SNF4SGF PNL MON.LT SNF 113E303 SH 6
797 36A-3FD	R.C. PUMP CCW SUPPLY ISOLATION VALVE	6/130 *127A	C/10	Q/FAI	797-C2 C-B1IX 797-C	SW.ONSNF PNL. IND.LTS.-SNF4SGF PNL MON.LT SNF 113E303 SH 6
822A 36A-1FM	RESIDUAL HEAT EXCHANGER CCW SHUT-OFF VALVE	5/129 *127A	C/10	Q/FAI	822A-02 SI-10X 822A-0	SW.-SGFPNL. IND.LTS.SGFF SBIFPNL. MON.LT.-SBIF PNL 113E303 SH 4
822B 36B-1FM	RESIDUAL HEAT EXCHANGER CCW SHUT-OFF VALVE	5/129 *127A	C/10	Q/FAI	822B-02 SI-20X 822B-0	SW.-SGFPNL. IND.LTS.-SGF MON.LT.-SBIF PNL 113E303 SH 4

NOTE:

- 1. SWITCH LEGEND PLATE TO BE ENGRAVED "CLOSE-OPEN"
- 2. * REFERS TO CABLE SCHEM. 9821-LL-21263 SH.

TERA APERTURE CARD
RRC APERTURE CARD

OPER. MODE

- O: NORMALLY OPERATED OPEN
- C: NORMALLY OPERATED CLOSED
- X: NORMALLY OPERATED OPEN & CLOSED
- FC: FAILED CLOSED
- FQ: FAILED OPEN
- FAI: FAILED AS IS

10	ECN-9750 W.C.D.P. 3-73 5-3-73 V. med 5-3-73
9	ECN-1665 J.S. 6-16-71 J.S. 6-16-71 J.S. 6-16-71 J.S. 6-16-71
8	ECN-1151 J.S. 3-31-71 J.S. 4-2-71
7	ECN-6887 V. MEARS 12/17/70 V. MEARS 1/11/71 V. MEARS 1/15/71
6	ECN-6651 J. SHERWOOD 10/11/70 J. SHERWOOD 12/8-70 J. SHERWOOD 12/19/70
5	ECN-6811 J.P. 10/17/70 J.P. 11/10/70 J.P. 11/10/70
4	ECN-6325-610-70 CHANGES BACKLOGGED PARKER PARKER 6-11-70 PARKER 6/11/70 PARKER 6/11/70
3	ECN-5501M SHERWOOD 5/26/70 SHERWOOD 5/26/70 SHERWOOD 5/26/70 SHERWOOD 5/26/70
2	ECN 5522 R.W. KEMERER 12/16/69 R.W. KEMERER 1/14/70 R.W. KEMERER 1/15/69

Westinghouse Electric Corporation

TITLE: CONSOLIDATED EDISON CO
INDIAN POINT STATION - UNIT No 3

ELEMENTARY WIRING DIAG VALVE TABLE - MOV

R.W. KEMERER 5/3/69 7/11/69 8/11/69

500B971

SHEET - III

ATOMIC POWER DIV. PITTSBURGH, PA., U.S.A.

8110230130