

Received w/Ltr 6-28-73

TERA APERTURE CARD

VALVE (MCC LOC)	FUNCTION	FIG. SH	SW SH	OPER SH MODE	* INTERLOCKS OR AUTO CONT. CONTACT	REF. DWG. & REMARKS
842 36A-7FM	MIN FLOW ISOLATION VALVE	8/132 *127A	C/10	%FAI	ON 842-C2 ON 43/RS-5 ON 842-C	SW LGTS SBIF PNL MON LGTS SBIF ANN SH.160 LT SH.147
843 36B-7FM	MIN FLOW ISOLATION VALVE	8/132 *127A	C/10	%FAI	ON 843-C2 ON 43/RS-5 ON 843-C	SW LGTS SBIF PNL MON LGTS SBIF ANN SH.160 LT SH.147
743 36A-7RM	RESIDUAL HEAT REMOVAL LOOP OUTLET VALVE	8/132 *127A	C/10	%FAI	ON 743-C2 ON 43/RS-5 ON 743-C	SW LGTS SNF PNL MON LGTS SBIF ANN SH.160 LT SH.147
1870 36B-7RM	RESIDUAL HEAT REMOVAL LOOP OUTLET VALVE	8/132 *127A	C/10	%FAI	ON 1870-C2 ON 43/RS-5 ON 1870-C	SW LGTS SNF PNL MON LGTS SBIF ANN SH.160 LT SH.147
747 36A-6RM	RESIDUAL HEAT LOOP DISCHARGE STOP VALVE	8/132 *125B	C/10	%FAI	ON 747-C2 ON 43/RS-5 ON 1870-C	SW-5GF PNL IND. LGTS-5GF SBIF ANN SH.160 MON. LGT. -SBIF ANN SH.160 LT SH.147
899B 36B-6RM	RESIDUAL HEAT LOOP DISCHARGE STOP VALVE	8/132 *125B	C/10	%FAI	ON 899B-C2 ON 43/RS-5 ON 1870-C	SW-5GF PNL IND. LGTS-5GF SBIF ANN SH.160 MON. LGT. -SBIF ANN SH.160 LT SH.147
856G 36A-4FM	HIGH HEAD INJECTION LINE STOP VALVE	4/128	C/10	C/FAI	ON 856G-C2 ON 43/RS-5 ON 1870-C	SW SB2F PNL IND. LGTS-SB2F PNL MON. LT. SB2F ANN SH.160 SEE NOTE 1
856H 36B-4FM	HIGH HEAD INJECTION LINE STOP VALVE	20/155	C/10	%FAI	ON 856H-02 ON SI-2IX ON 856H-0	SW/LGTS SB2F RELAY SBIR MON. LT. SB2F PNL 856H-VX ANN SH.160 113E303 SH. 4
856J 36B-8FM	HIGH HEAD INJECTION LINE STOP VALVE	*125A	C/10	%FAI	ON 856J-02 ON SI-22X ON 856J-0	SW/LGTS SB2F RELAY SBIR MON. LT. SB2F PNL 856J-VX ANN SH.160 113E303 SH. 4
856K 36A-8FM	HIGH HEAD INJECTION LINE STOP VALVE	20/155 *125A	C/10	%FAI	ON 856K-02 ON SI-11X ON 856K-0	SW/LGTS SB2F RELAY SB2R MON. LT. SB2F PNL 856K-VX ANN SH.160 113E303 SH. 4

OPER. MODE
 O= NORMALLY OPERATED OPEN
 C= NORMALLY OPERATED CLOSED
 X= NORMALLY OPERATED OPEN & CLOSED
 FC= FAILED CLOSED
 FO= FAILED OPEN
 FAI= FAILED AS IS

NOTE 1. SWITCH LEGEND PLATE TO BE ENGRAVED CLOSE-OPEN
 2. REFERS TO CABLE SCHEM. 9321-LL-31263 SH.
 ECN-70058

PRC APERTURE CARD

9	ECN-9750 WCD 5-3-73 5-3-73
00	ECN-9557 CHANGES RECIRCLED HEARS 10-25-72 11-15-72
1	ECN-1665 1-9-76-71 1-22-76-23-71 1-22-76-23-71
0	ECN-7161 1-9-3-9-71 3-31-71
0	ECN-6987 W. MEARS 12/21/70 1/4/71
4	ECN-6811 WRS-10-26-70 19-27-70
3	ECN-6329 BACKCIRCLED 6-10-70 PARKER
2	ECN-5117 SERBER 5/17/70 5/17/70
SUB	SO. INT-305

Westinghouse Electric Corporation

TITLE: CONSOLIDATED EDISON CO. INDIAN POINT STATION UNIT NO. 3

ELEMENTARY WIRING DIAG. VALVE TABLE - MOV

R.W. KEMERER 12/1/69
Hudson 9/14/69

500B971

SHEET-117

ATOMIC POWER DIV., PITTSBURGH, PA., U.S.A.

8110230137