



PER ITEM 617 OF EUP-367

IN LOCAL STARTER UNLESS OTHERWISE NOTED

TO ENGINE 31 MTD STARTER ENCLOSURE FOR JACKET WATER HTR, LUBE OIL HEATER, & PRE-LUBE PUMP
FP. #1321-05-3477

NOTES:

- * 1- FOR DEVICE 1/ACI SEE SHEET 1 ARRGT 2
- * 2- FOR DEVICE 1/ACI SEE SHEET 1 ARRGT 2
- * 3- DEVICE 63/ACI CLOSES ON PRESS DECREASE TO 275 PSI AND OPENS ON INCREASE TO 300 PSI
- * 4-
- * 5-
- * 6-
- * 7- FOR DEVICE M5 SEE FP#1321-05-2852
- * 8- LETTER (C) REFERS TO CABLE SCHEMATIC SHEET 2A
- * 9- LETTER (C) REFERS TO CABLE SCHEMATIC SHEET 2B

EXH HOOD VENT BLOWER 31
WIRE PREFIX "VBI"

DIESEL GEN. 31 AIR COMPRESSOR
WIRE PREFIX "ACI"

4	21	REVISED PER ITEM 617 OF EUP-367			
3	21	REM. CUL.(C) SYM. FR. WIRES C1 & C			
2	11	42 INDINGS WERE INCORRECTLY PRINTED IN			
1	15	ADDED CABLE PER LETTERS & NOTES ABOVE FOR CONSTRUCTION			
9	15	FIRST ISSUE FOR CONSTRUCTION			
	DATE	DESCRIPTION	ENGR	SUP. ENGR	(W)
ENGINEER					
STATE REG. NEW YORK		NO. 142453			
UNITED ENGINEERS & CONSTRUCTORS INC.					

WESTINGHOUSE ELECTRIC CORPORATION FOR CONSOLIDATED EDISON COMPANY INDIAN POINT GENERATING STATION - UNIT NO. 3	
SCHEMATIC DIAGRAM DIESEL GENERATOR AUXILIARIES	
SHEET NO. 2	
U.E. & C. DWG. NO.	CON. ED. CO. DWG. NO.
9321-LL-31333	D202471

6245

8111030044

RECEIVED
JUL 10 1974
U.S. ATOMIC ENERGY
COMMISSION
Regulatory
Mail Section