


CONTROL TRANSFERRED TO LOCAL - SEE SH. 16 & 5
COMMON SAFEGUARDS LOCK-OFF ALARM - SEE SH. 7

- NOTES
- * 1- WIRE DESIGNATIONS ARE TO BE PREFIXED WITH GO.
 - * 2- NUMBERS IN SQUARES REFER TO EQUIPMENT LOCATION. FOR LEGENDS SEE SH. 1
 - * 3- FOR DEVICE 1/AFI DEVELOPMENT SEE DEVICE 1/x. 9321-LL-31173, SH. 3
 - * 4- FOR DEVICE TDC/APPRI SEE 9321-LL-31313, SH. 10
 - * 5- FOR DEVICE 27-3A/X3 3-2/3A, 63-1/3A SEE 9321-LL-31173, SH. 6
 - * 6- DEVICE 2-1 TIME DELAY ON ENERGIZATION.
 - * 7- FOR DEVICE 43/AFI SEE SH. 6
 - * 8- FOR DEVICE BFP SEE SH. 5
 - * 9- LETTER (A) ETC. REFERS TO CABLE SCHEMATIC, SH. 11A.

480V SWGR. MOTOR TRIP (ALARM WIRED OUT)
COMMON-SEE SH. 16 & 31

9321-LL-31313 SH. 10



ADDED NEW SH. # 5

6	12/27	DELETED LTD. (C) FROM WIRE			
5	12/27	REVISED NOTE # 6			
4	24/77	ADDED 8 REL. SEE CABLE LETTERS			
3	13/21	ADDED WAS 43/AFI DEVELOPMENT			
2	23/31	ADDED CABLE LETTERS & NOTES			
1	16/1	GENERAL REVISION			
0	1/1	FIRST ISSUE FOR CONSTRUCTION			
2	DATE	DESCRIPTION	ENGR	SUP ENG	(W)
ENGINEER		P. Johnson			
STATE REG. I.		NO. 44403			
UNITED ENGINEERS & CONSTRUCTORS INC.					

BREAKER S2/AFI
AUX. FEEDWATER PUMP 31

WESTINGHOUSE ELECTRIC CORPORATION
FOR
CONSOLIDATED EDISON COMPANY
INDIAN POINT GENERATING STATION - UNIT NO. 3

SCHEMATIC DIAGRAM
480V. SWITCHGEAR 32

SHEET NO. 11

U.E. & C. DWG. NO. 9321-LL-31183
CON. ED. CO. DWG. NO. D202470

6245

8110 30082

