



AUTO CLOSE - PERMISSIVE TO OPEN
FIGURE #10

VALVE SHOWN IN FULL OPEN POSITION

- NOTE:
1. WIRE DESIGNATIONS ARE TO BE PREFIXED WITH VALVE NO.
 2. LETTER (A) ETC. REFERS TO CABLE SCHEMATIC.
 3. RELAY 33acx TO BE PREFIXED WITH VALVE NO. REF DWG 113E302, SH2
 4. "P" OPENS ON INCREASING R.C.S. LOOP PRESSURE.
 5. "A" CLOSSES ON INCREASING R.C.S. LOOP PRESSURE.

VALVE	P	A
730 REF DWG 113E302, SH1&2	PC402AX 17 21	PC402BX 17 21
731 REF DWG 113E302, SH3	PC403AX 17 21	PC403BX 17 21

Westinghouse Electric Corporation

TITLE: CONSOLIDATED EDISON CO.
INDIAN POINT STATION - UNIT #3
ELEMENTARY WIRING DIAG. MOTOR OPERATED VALVE

M. HASEGAWA 3864 [Signature] [Date]

8 7 1 SUB S.O. INT-385

500B971
SHEET-134

ATOMIC POWER DIV., PITTSBURGH, PA., U.S.A.

810010118