

<b>NRC FORM 699</b> (9-2003)		<b>U.S. NUCLEAR REGULATORY COMMISSION</b>		DATE 01/27/2010
<b>CONVERSATION RECORD</b>				TIME 3:30 PM
NAME OF PERSON(S) CONTACTED OR IN CONTACT WITH YOU Glenn Adams		TELEPHONE NO. 612-330-6777		TYPE OF CONVERSATION <input type="checkbox"/> VISIT <input type="checkbox"/> CONFERENCE <input checked="" type="checkbox"/> TELEPHONE <input type="checkbox"/> INCOMING <input checked="" type="checkbox"/> OUTGOING
ORGANIZATION PI-HSFSI - Northern States Power Company, a Minnesota corporation (NSPM)				
SUBJECT Suspension of the TN-40HT Licensing Amendment Request (LAR) review Docket No. 72-10; SNM-2506				
SUMMARY (Continue on Page 2)				
<p>List of Participants          NRC: Pamela Longmire, Ph.D., JoAnn Ireland, Robert Einziger, Earl Love, Ron Parkhill, David Tang, Geoffrey Hornseth, and Michael Waters          NSPM: Glenn Adams, Oley Nelson, and Gary Wheelock          TN: Peter Shih, Bill Bracey, and Steve Streucker</p> <p>SFST Staff requested this conference call because NSPM's supplement to the LAR [ML100210197] contained responses to the request for additional information (RAI) that were either incomplete and inadequate or unacceptable. Based on these responses SFST Staff was not able to make a safety determination. Therefore, the purpose of the conference call was to obtain clarification on the responses provided in relation to: 1) quality/safety classifications; 2) FSAR drawing notes (i.e., "materials meeting JIS code or equivalent national standard may be used in lieu of ASTM materials"); and 3) confinement leak testing.</p> <p>For safety classifications, NSPM plans to offer some text or table to assist SFST Staff reconcile the ITS Categories A, B, C with the Prairie Island Nuclear Generating Plant (PINGP) categories SR, AQ, NSR. During the discussion of FSAR drawing notes regarding ASTM, the applicant claimed existence of past agreements on this matter. TN will look for previous agreements with the Staff on how this issue was resolved for other submittals. Also, TN will consider the alternative language ("equivalency with TN approval") offered by SFST Staff. On leak testing of the entire confinement boundary: Staff's position was stated as per draft ISG-25 ("Pressure and Helium Leakage Testing of the Confinement Boundary of Spent Fuel Storage Casks"); TN and NSPM will revisit the response provided to the RAI.</p> <p>The review will be suspended until NSPM provide a supplement with complete responses to the RAI. NSPM requested a follow-up conference call. Staff agreed (tentatively) to support the conference call on Monday (February 1, 2010).</p> <p>Call ended approximately 4:45 PM. <span style="float: right;">+</span></p> <p><b>Continue on Page 2</b></p>				
ACTION REQUIRED The NRC will consider the RAI response received when the requested supplemental information is received. As such, NRC review of the application is currently on hold until the supplemental information is received.				
NAME OF PERSON DOCUMENTING CONVERSATION Pamela Longmire, Ph.D.		SIGNATURE /RA/		DATE 01/27/2010
ACTION TAKEN Suspended review of request to amend license SNM-2506 (Docket No. 72-10).				
TITLE OF PERSON TAKING ACTION Pamela Longmire, Ph.D.		SIGNATURE OF PERSON TAKING ACTION /RA/		DATE 01/27/2010