A202401

N

SECTION U-U
SCALE 1/4"=1'-0"

SECTION Q-Q
N.T.S.

SECTION V-V
SCALE 1/4"=1'-0"

DETAIL-N
SCALE 1"=1'-0"

SECTION G-G
SCALE 1/4"=1'-0"

SECTION M-M
SCALE 1/4"=1'-0"

SECTION L-L
SCALE 1/4"=1'-0"

SECTION K-K
SCALE 1/4"=1'-0"

SECTION A-A
SCALE 1/4"=1'-0"

SECTION B-B
SCALE 1/4"=1'-0"

SECTION H-H
SCALE 1/4"=1'-0"

SECTION F-F
SCALE 1/4"=1'-0"

DETAIL-C
SCALE 1"=1'-0"

PLAN-EL 33'-0"
SCALE 1/4"=1'-0"

PLAN-EL 49'-0"
SCREENED

STRIP HEATER PANEL №32
208/120 VOLTS, 3Φ, 4W
EL. 33'-0"
WALL

STRIP HEATER PANEL №31
208/120 VOLTS, 3Φ, 4W
EL. 5'-0"
WALL

BATTERY №32 (GE)

BATTERY №31

NOTES
1. ALL UNDERGROUND CONDUITS SHALL HAVE A MIN. SLOPE OF 6" PER 100'-0".
2. SEE LIST OF PLANT SYMBOLS DWG. 9321-F-30003 FOR LOCATION OF EQUIPMENT.
3. FOR CONDUITS NOT SHOWN HEREON SEE DWG. 9321-F-32001 SH. 1 & 2.

PRC APERTURE CARD
A210114-1

REVISED AS BUILT & FINAL					
NO.	DATE	DESCRIPTION	ENGR.	SUP'VSR.	CK.
		FIRST ISSUE			

ENGINEER
STATE REG. NO.
UNITED ENGINEERS & CONSTRUCTORS INC.

WESTINGHOUSE ELECTRIC CORPORATION
SERVICE WATER PUMP #31 THRU #39
CONDUIT LAYOUT
CONTROL BUILDING
FOR
CONSOLIDATED EDISON COMPANY
INDIAN POINT GENERATING STATION
UNIT NO. 3

D. E. & C. DWG. NO. 9321-F-30893 (3)
CON. EDISON CO. DWG. NO. A202401

TERA APERTURE CARD

POOR ORIGINAL

8110300168