FLOW DIAGRAM BOILER FEEDWATER

INDIAN POINT NO.3 NUCLEAR POWER PLANT

NewYorkPower Authority

DWG NO ISI-20193 REV 3

SCALE

SHEET OF

SI APERTURE CARD

Docket # 50-286
Accession # 9006270025
Date 6/18/90 of Ltr
Regulatory Docket File

REV NO	DATE	DESCRIPTION	TD	DWN	DS	DE	PROJ APP.
3	6/18/90	UPDATED TO 9321-F-20193, REV.29.					

REVISIONS

DWN	CHK'D
DES SUPV	
DISCIPLINE ENG	
DISCIPLINE MGR.	
PROJ APPROVAL	
DATE	

DESCRIPTION

FLOW DIAGRAM SYMBOLS
YARD AREA-WEST OF CONTAINMENT BLDG.-BOILER FEED PIPING PLAN-SH.1
AUXILIARY FEED PUMP BLDG.-AUXILIARY FEEDWATER PIPING-SH.1
CONVENTIONAL LINE SCHEDULE CLASS -1 PIPING.
NUCLEAR LINE SCHEDULE.(CLASS 1 INCLUDED)
FLOW DIAGRAM AUXILIARY BOILER FEED PUMP RECIRCULATION.

CLASS, PIPING

1. MAIN FEEDWATER FROM INLET OF BFD-6 CHECK VALVE TO EACH STEAM GENERATOR INCLUDING CONNECTED INSTRUMENTS.
2. COMPLETE AUX.FEEDWATER SYSTEM INCLUDING PUMPS & DRIVES. RECIRCULATION & DISCHARGE PIPING & INSTRUMENTATION PLUS ALL CONNECTED VENTS & DRAINS.

U.E.& C. DWG.NO.	REFERENCE DRAWINGS CON.ED.DWG.NO.
9321-C-20163	C-201815
-F-20613	A-201860
-F-21263	A-201925
-C-23003	C-202787
-C-27413	C-202251
6604-114-D-1	

NOTES:

1. ALL VALVES NUMBERS ARE PRECEDED BY "BFD"UNLESS OTHERWISE NOTED.
2. THESE VALVES ARE IN A LOCKED THROTTLE POSITION
3. (XX) =PENETRATION NUMBER(REF.F.S.A.R.)
4. THIS DWG.SHALL BE USED ONLY FOR DETERMINING THE EXTENT OF THE INSERVICE INSPECTION BOUNDARIES.
5. BOUNDARIES SHOWN TO INCLUDE BOUNDARY VALVES WHERE APPROPRIATE.THE ACTUAL PRESSURE RETAINING I.S.I.BOUNDARIES FOR LEAKAGE AND HYDROSTATIC TESTING EXTEND ONLY TO VALVE INTERNALS THAT COMPRISE THE EFFECTIVE OBTURATOR ASSEMBLY.

ISI LEGEND
---1---1--- ISI CLASS I
---2---2--- ISI CLASS II
---3---3--- ISI CLASS III

THIS ISI DWG.IS BASED ON U.E.& C.DWG.#9321-F-20193, REV.29