

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
CONSOLIDATED EDISON COMPANY) Docket No. 50-247
OF NEW YORK, INC.)
(Indian Point Station,)
Unit No. 2))

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission (NRC), Consolidated Edison Company of New York, Inc. (Con Edison), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A to that license.

Specifically, we request that Technical Specification 3.10 be revised to limit control rod misalignment to no more than 12 steps from its control rod bank demand position. This Application is being submitted in response to the letter dated October 29, 1979 from Mr. A. Schwencer (NRC) to Mr. William J. Cahill, Jr. (Con Edison).


The specific proposed Technical Specification revisions are set forth in Attachment A to this Application. A Safety Evaluation of the proposed changes is set forth in Attachment B to this Application. This evaluation

8001090 318

demonstrates that the proposed changes do not represent a significant hazards consideration and will not cause any change in the types or an increase in the amounts of effluents or any change in the authorized power level of the facility.

CONSOLIDATED EDISON COMPANY
OF NEW YORK, INC.

By:


William J. Cahill, Jr.
Vice President

Subscribed and sworn to
before me this 28 day of
December, 1979.



Notary Public

ANGELA ROBERTI

Notary Public, State of New York

No. 41-8593813

Qualified in Queens County

Commission Expires March 30, 1980