

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
CONSOLIDATED EDISON COMPANY)	Docket No. 50-247
OF NEW YORK, INC.)	
(Indian Point Station,)	
Unit No. 2))	

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE


Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission (NRC), Consolidated Edison Company of New York, Inc. ("Consolidated Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A of that license.

Specifically, it is requested that technical specifications 2.3, 3.10, 5.3 and Tables 3-2 and 4.1-1 be modified to support a planned fuel design change from high parasitic (HIPAR) fuel to low parasitic (LOPAR) fuel. These technical specification changes were determined to be necessary following completion of the detailed analytical and testing program which demonstrated the acceptability of the planned fuel transition.


The specific proposed Technical Specification revisions are set forth in Attachment A to this Application. A Safety Evaluation of the proposed

changes is set forth in Attachment B to this Application. This evaluation demonstrates that the proposed changes do not represent a significant hazards consideration and will not cause any change in the types or an increase in amounts of effluents or any change in the authorized power level of the facility.

CONSOLIDATED EDISON COMPANY
OF NEW YORK, INC.

By: 
William J. Cahill, Jr.
Vice President

Subscribed and sworn to
before me this 21 day
of May, 1980.


Notary Public
- ANGELA ROBERTI
Notary Public, State of New York
No. 41-8593813
Qualified in Queens County
Commission Expires March 30, 1982