

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter Of )  
 )  
CONSOLIDATED EDISON COMPANY ) Docket No. 50-247  
OF NEW YORK, INC. )  
(Indian Point Station, )  
Unit No. 2) )

APPLICATION FOR AMENDMENT TO  
OPERATION LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission ("NRC"), Consolidated Edison Company of New York, Inc. ("Consolidated Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A of that License. Specifically, Consolidated Edison requests that the action statement in technical specification 3.3.A.2.a be modified to allow, on a one time only basis, continued power operation for a period of seven days with safety injection pump 23 out of service.

The specific proposed Technical Specification page revision is set forth in Attachment A to this Application. A Safety Evaluation of the proposed changes is set forth in Attachment B to this Application. This evaluation demonstrates that the proposed changes do not represent a significant hazards consideration and will not cause

any change in the types or an increase in the amounts of effluents  
or any change in the authorized power level of the facility.

CONSOLIDATED EDISON COMPANY  
OF NEW YORK, INC.

By: George Wosilakofa  
John D. O'Toole  
Vice President

Subscribed and sworn to  
before me this 11 day  
of August, 1981.

D. J. Watson  
Notary Public