

John D. O'Toole
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 460-2533

March 26, 1982



Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

ATTN: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

Re: Consolidated Edison Company of New York, Inc.
(Indian Point Station, Unit No. 2)
Docket No. 50-247

Dear Mr. Varga:

Consolidated Edison Company of New York, Inc. transmits herewith three (3) signed originals and forty (40) copies of the document entitled "Application for Amendment to Operating License", sworn to on March 26, 1982. This Application formally requests on a one-time only basis an additional fifteen day extension to the maximum time between tests specified in Table 4.1-3 of the Technical Specifications for the turbine stop and control valve closure test. This amendment was previously requested by letter dated March 24, 1982. Telephone authorization was received on March 24, 1982 with subsequent written confirmation provided by your letter dated March 25, 1982. The text of the requested modifications and a Safety Evaluation are attached to the application papers.

In accordance with 10 CFR 170.22, this Application qualifies as a "Class III" Amendment. Accordingly, as required by 10 CFR 170.22, enclosed is a check in the amount of \$4,000.00 as the total filing fee for this Application. This payment is being made under protest, and Consolidated Edison reserves the right to challenge the validity of the imposition of these fees, and the basis for the determination of the amounts of the fees.

An Affidavit of Service is enclosed.

Very truly yours,

cc: (w/encl.)
Hon. George V. Begany

A001
//
w/check:
\$4000.00

8204010314 820326
PDR ADOCK 05000247
P PDR