

TABLE 4.1-3

FREQUENCIES FOR EQUIPMENT TESTS

	<u>Check</u>	<u>Frequency</u>	<u>Maximum Time Between Tests</u>
1. Control Rods	Rod drop times of all control rods	Each refueling shutdown	**
2. Control Rods	Partial movement of all control rods	Every 2 weeks during reactor critical operations	20 days
3. Pressurizer Safety Valves	Set point	Each refueling shutdown	**
4. Main Steam Safety Valves	Set point	Each refueling shutdown	**
5. Containment Isolation System	Automatic Actuation	Each refueling shutdown	**
6. Refueling System Interlocks	Functioning	Each refueling shutdown prior to refueling operation	NA*
7. DELETED			
8. Diesel Fuel Supply	Fuel Inventory	Weekly	10 days
9. Turbine Steam Stop, Control Valves	Closure	Monthly****	45 days**** +
10. Cable Tunnel Ventilation Fans	Functioning	Monthly	45 days
11. Control Room and Fuel Handling Building Filtration System	Charcoal Filter Pressure Drop Test < 5 inches of water visual inspection Freon - 112 (or equivalent) test $\geq 99.5\%$ at ambient conditions	Each refueling shutdown prior to refueling operation***	**

Amendment No.

+ One-time only exception, the 45-day maximum time between tests may be extended to 60 days ending at 11:59 P.M. on April 8, 1982.