

John D. O'Toole
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 460-2533

August 2, 1985

Re: Indian Point Unit No. 2
Docket No. 50-247

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

ATTN: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

Dear Mr. Varga:

Consolidated Edison Company of New York, Inc. (Con Edison) transmits herewith three (3) signed originals and forty (40) copies of a document entitled "Application for Amendment to Operating License," sworn to on August 2, 1985. This Application requests an amendment to the Technical Specifications for Indian Point Unit No. 2. The proposed Technical Specification changes, contained in Attachment A to this Application, would establish limiting conditions for operation (LCOs) and surveillance requirements for the Alternate Safe Shutdown System of Indian Point Unit No. 2. These changes were requested by the Regulatory Staff as a result of its review of the Indian Point 2 evaluation of fire protection of safe shutdown capability for Section III.G of 10 CFR 50, Appendix R. These proposed Technical Specification changes supersede those in our August 7, 1981 amendment request, which was returned for resubmittal by letter dated November 15, 1983 (S. A. Varga to J. D. O'Toole). A Safety Assessment of the proposed changes is presented in Attachment B to this Application.

The appropriate filing fee, in accordance with 10 CFR 170.12, is enclosed along with an Affidavit of Service attesting to state and local notification as required by 10 CFR 50.91.

8508070275 850802
PDR ADOCK 05000247
P PDR

*Acob w/check \$150⁰⁰
1/40 #0583432*

We request that these proposed Technical Specifications become effective at least 6 months after issuance of the license amendment to allow sufficient time to prepare procedures and conduct the initial surveillance.

Very truly yours,



John D. O'Toole
Vice President

encl.

cc: Hon. Cheryl Harding (w/encl.)
Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

Mr. Jay Dunkelberger (w/encl.)
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Plaza
Albany, New York 12223

Senior Resident Inspector (w/encl.)
U. S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, New York 10511