

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
CONSOLIDATED EDISON COMPANY) Docket No. 50-247
OF NEW YORK, INC.)
(Indian Point Station,)
Unit No. 2))

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE


Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission ("NRC"), Consolidated Edison Company of New York, Inc. ("Consolidated Edison") as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A of that license.

Specifically, it is requested that technical specification 3.8.A.1 be revised to include a provision for utilizing a temporary closure plate in place of the equipment door during refueling. This proposed change is being requested to improve the efficiency of refueling outage work. The temporary closure plate will provide penetrations for temporary services which will enable many maintenance activities to be performed while maintaining primary containment integrity during core alterations or fuel movement. Use of the temporary closure plate will improve outage scheduling flexibility without compromising the intent of the existing specification.


8508160184 850806
PDR ADOCK 05000247
P PDR

The specific proposed Technical Specification revisions are set forth in Attachment A to this Application. A Safety Assessment of the proposed changes is set forth in Attachment B to this Application. This assessment demonstrates that the proposed changes do not represent a significant hazards consideration as defined in 10 CFR 50.92(c) and will not cause any change in the types or an increase in amounts of effluents or any change in the authorized power level of the facility.

CONSOLIDATED EDISON COMPANY
OF NEW YORK, INC.

BY: 
John D. O'Toole
Vice President

Subscribed and sworn to
before me this 6 day
of August, 1985.


Notary Public

CONRAD TROMBA
Notary Public, State of New York
No. 30-4022875
Qualified in Nassau County
Terms expires March 30, 1987.