

Murray Selman
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Ave.
Buchanan, NY 10511
Telephone (914) 737-8116

May 23, 1986

Re: Indian Point Stations Unit 2
Docket No. 50-247

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attn: Mr. Steven A. Varga, Director
PWR Project Directorate No. 3
Division of PWR Licensing - A

Dear Mr. Varga:

Confirming discussions with members of your staff today, we hereby request an immediate change to the Indian Point Unit No. 2 Technical Specifications. This change would permit on a one-time only basis relief from Technical Specification 3.4.B which currently requires that within 72 hours after discovery that a minimum of twenty (20) ASME code approved steam-relieving main steam valves are not operable (except for testing), the reactor shall be placed in the hot shutdown condition within the next 12 hours. The requested change to Technical Specification 3.4.B would extend the 72-hour limiting condition of operation for a period not to exceed an additional two weeks.

The Safety Assessment and Basis for No Significant Hazards Consideration Determination are attached. In addition, the proposed technical specification page revision is attached.

Very truly yours,

Murray Selman

cc: Senior Resident Inspector
P.O. Box 38
Buchanan, NY 10511

8606030197 860523
PDR ADOCK 05000247
Q PDR

A047
/1