

Murray Selman
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

August 18, 1986

Re: Indian Point Unit No. 2
Docket No. 50-247

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

ATTN: Mr. Steven A. Varga, Project Director
PWR Project Directorate No. 3
Division of PWR Licensing - A

Re: Consolidated Edison Company of New York, Inc.
Indian Point Station, Unit No. 2
Docket No. 50-247

Transmitted herewith are three (3) signed originals and forty (40) copies of the document entitled, "Application for Amendment to Operating License" sworn to on August 18, 1986. This Application requests an amendment to the Technical Specifications for Indian Point Unit No. 2.

The proposed Technical Specification changes, contained in Attachment A to the Application, are in response to NRC's June 16, 1986 letter, which requested Consolidated Edison to submit Technical Specification changes that are responsive to Generic Letter 85-09, entitled "Technical Specifications For Generic Letter 83-28, Item 4.3", and June 22, 1984 Safety Evaluation Report (SER) for a modification to Indian Point Unit No. 2 to provide automatic actuation of the reactor trip breakers shunt trip attachment consistent with item 4.3 of Generic Letter 83-28. Plant specific details of this modification were provided to NRC by Consolidated Edison in letters dated April 2, 1984 and June 22, 1984. The generic design was developed by Westinghouse for the Westinghouse Owner's Group (WOG) and submitted on June 14, 1983. The modification was implemented during the cycle 6/7 refueling outage. The WOG has undertaken a program aimed at optimizing reactor trip breaker test and maintenance practices. Subsequent Technical Specification changes may be requested as a result of that work.

860E220087 860818
PDR ADOCK 05000247
PDR

Aoss
w/ check oo
\$150.00
#498122

August 18, 1986

Re: Indian Point Unit No. 2
Docket No. 50-247

A Safety Assessment justifying the proposed changes and concluding that this amendment does not involve a significant hazards consideration is contained in Attachment B to this Application.

The appropriate filing fee, in accordance with 10 CFR 170.12 is enclosed (check No. E498122) along with an Affidavit of Service attesting to state and local notification as required by 10 CFR 50.91.

Very truly yours,



encl.

cc: Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, New York 10511

Mr. Jay Dunkleberger
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Plaza
Albany, New York 12223

Hon. Alfred J. Donahue
Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
CONSOLIDATED EDISON COMPANY) Docket No. 50-247
OF NEW YORK, INC.)
(Indian Point Station,)
Unit No. 2))

STATE OF NEW YORK)
) ss:
COUNTY OF NEW YORK)

AFFIDAVIT OF SERVICE

Branislav A. Raskovic, being duly sworn, states:

That he is an Engineer employed by Consolidated Edison Company of New York, Inc., and that he has served the foregoing document, sworn to on August 18, 1986, entitled "Application for Amendment to Operating License" by mailing copies thereof, first class postage prepaid and properly addressed to the following persons:

Mr. Jay Dunkleberger
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Plaza
Albany, New York 12223

Hon. Alfred J. Donahue
Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

B. Raskovic

Branislav A. Raskovic

Subscribed and sworn to
before me this 18 day
of August, 1986.

Conrad Tromba

CONRAD TROMBA
Notary Public, State of New York
No. 30-4022875
Qualified in Nassau County
Terms expires March 30, 1987

Notary Public