

Murray Selman
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

May 29, 1987

Re: Indian Point Unit No. 2
Docket No. 50-247

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555


Dear Sirs:

Consolidated Edison Company of New York, Inc. transmits herewith a signed original and thirty seven (37) copies of a document entitled "Application for Amendment to Operating License," sworn to on May 29, 1987. This application requests an amendment to the Indian Point Unit No. 2 Technical Specifications to permit an extension of the maximum surveillance interval limits for various systems and components to allow refueling surveillance tests listed in Table 1 of this letter to be performed during the 1987 refueling outage. The text of the requested Technical Specification changes and a Safety Assessment are attached to the Application.

The appropriate filing fee, in accordance with 10 CFR 170.12 is enclosed, together with an Affidavit of Service attesting to state and local notification as required by 10 CFR 50.91.

Issuance of this proposed change would avoid an unnecessary and unwarranted plant shutdown simply to perform certain surveillance tests. We therefore request your expeditious approval of this proposed amendment since the earliest surveillance test would otherwise have to be performed as early as September, 1987. If the proposed change is granted the affected surveillance tests will all be performed during the upcoming refueling and maintenance outage presently scheduled to commence in November of 1987.

Very truly yours,



20.190.4.15.2
Enclosure

8706080098 870529
PDR ADOCK 05000247
P PDR

Rec'd w/ check \$150.00

A001
11

cc: Hon. Alfred J. Donahue (w/encl.)
Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Mr. Jay Dunkelberger (w/encl.)
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Plaza
Albany, NY 12223

Senior Resident Inspector (w/encl.)
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, NY 10511

Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Ms. Marylee M. Slosson, Project Manager
PWR Project Directorate #3
Division of PWR Licensing - A
U.S. Nuclear Regulatory Commission
Philips Building
7920 Norfolk Avenue
Bethesda, MD 20014

TABLE 1
 SURVEILLANCE INFORMATION IN SUPPORT
 OF PROPOSED TECHNICAL SPECIFICATION
 CHANGE ON MAXIMUM SURVEILLANCE INTERVALS

<u>TEST NO.</u>	<u>TEST DESCRIPTION</u>	<u>TECH SPEC REFERENCE</u>
PC-R1A	RCS LOOPS HOT AND COLD LEGS NARROW RANGE TEMPERATURE	Table 4.1-1 Item 4
PC-R3	PRESSURIZER LEVEL	Table 4.1-1 Item 6
PC-R4	PRESSURIZER PRESSURE	Table 4.1-1 Item 7
PC-R5A	6.9 KV UNDERVOLTAGE AND RESPONSE TIME	Table 4.1-1 Item 8
PC-R7	STEAM GENERATOR LEVEL	Table 4.1-1 Item 11
PC-R13	VOLUME CONTROL TANK LEVEL	Table 4.1-1 Item 17
PC-R15B	AREA RADIATION MONITOR	Table 4.1-1 Item 19
PC-R17B	ACCUMULATOR PRESSURE	Table 4.1-1 Item 22
PC-R18	STEAM LINE PRESSURE	Table 4.1-1 Item 22
PC-R20	INDEPENDENT ELECTRICAL OVERSPEED PROTECTION SYSTEM	Table 4.1-1 Item 24
PT-R5A	HOT SETTING OF PRESSURIZER SAFETY VALVES BY WYLE LABS	Table 4.1-3 Item 26
PT-R10	FAN COOLER UNITS FILTRATION	Section 4.5.D.2
PT-R40	FCU WATER SPRAY AND ALARM SYSTEM	Section 4.14.B
PT-R47	V.C. SMOKE DETECTOR OPERABILITY	Section 4.14.D
PT-R61	480 VOLT BREAKER UNDERVOLTAGE RELAYS	Table 4.1-1 Item 29
PI-V1A	SHOCK SUPPRESSOR (SNUBBER) VISUAL INSPECTION	Section 4.12.A