From: Feintuch, Karl
Sent: Monday, February 01, 2010 10:45 AM
To: mrasmuss@idph.state.ia.us
Subject: ME0789/0873/0874 (Exemption and amendments) State Consultation

To: **Melanie Rasmusson**, State Liaison Officer
Bureau Chief for Radiological Health
Iowa Dept of Public Health
Bureau of Radiological Health
Des Moines, IA 50319-0075
515-281-3478
mrasmuss@idph.state.ia.us

This message documents a call to your office and conversation on January 29, 2010.

Pursuant to 10CFR50.91(b) *State consultation*, notified you that we are processing an exemption to certain requirements of 10 CFR Part 50, Appendix J, Option B and an associated change to the Technical Specifications for main steamline isolation valve (MSIV) local leakage rate testing for Duane Arnold Energy Center. The associated change to the license of the Duane Arnold Energy Center (DAEC) revises Technical Specifications (TS) 5.5.12, (Primary Containment Leakage Rate Testing Program) Also, there is additional proposed Technical Specification change to Section 3.6.1.3 pertaining to the MSIVs, which does not require a corresponding exemption from 10 CFR Part 50, Appendix J

The 3 actions are described in the Licensee's application letter dated March 4, 2009. The letter may be accessed in ADAMS with the Accession Number ML090680040. The NRC tracks these actions with our assigned TAC Nos. ME0789 (the exemption), ME0873 (the amendment associated with the exemption), and ME 0874 (the amendment pertaining to the MSIVs, but not associated with an exemption).

I described the Licensee's application and rationale that they provided for these actions. You stated that you had no comments.

Thank you for you time in addressing this matter with me.

Karl Feintuch
Project Manager
USNRC
301-415-3079

E-mail Properties

Mail Envelope Properties ()

Subject: ME0789/0873/0874 (Exemption and amendments) State Consultation
Sent Date: 2/1/2010 10:42:19 AM
Received Date: 2/1/2010 10:44:00 AM
From: Feintuch, Karl

Created By: Karl.Feintuch@nrc.gov

Recipients:
mrasmuss@idph.state.ia.us (mrasmuss@idph.state.ia.us)
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	9532	2/1/2010

Options
Expiration Date:
Priority: olImportanceNormal
ReplyRequested: False
Return Notification: False

Sensitivity: olNormal
Recipients received: