

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION


In the Matter of)
)
CONSOLIDATED EDISON COMPANY) Docket No. 50-247
OF NEW YORK, INC.)
(Indian Point Station,)
Unit No. 2))

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission ("NRC"), Consolidated Edison Company of New York, Inc. ("Consolidated Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A of that license. Specifically, Consolidated Edison requests that a new Technical Specification 4.18.E and its associated basis be added to require a surveillance test of the backup nitrogen supply system to the pressurizer power operated relief valves.

The specific proposed Technical Specification revisions are set forth in Attachment A to this Application. A Safety Assessment of the proposed changes is set forth in Attachment B to this Application. This assessment demonstrates that the proposed changes do not represent a significant hazards considerations as defined in 10 CFR 50.92(c).

As required by 10 CFR 50.91(b)(1), a copy of this application and our analysis concluding that the proposed changes do not constitute a significant hazards consideration have been provided to the appropriate New York State official designated to receive such amendments.

BY: 
Stephen Bram
Vice President

8810030080 880923
PDR ADOCK 05000247
P PNU

Subscribed and sworn to
before me this 23 day
of September, 1988


Notary Public

~~ANTHONY R. ARNONE
Notary Public, State of New York
No. 4883047
Qualified in Westchester County
Commission Expires January 26, 1989~~

ANTHONY R. ARNONE
Notary Public, State of New York
No. 4883047
Qualified in Westchester County
Commission Expires January 26, 1989