

Stephen B. Bram
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

December 29, 1988

Re: Indian Point Station Unit No. 2
Docket No. 50-247

Document Control Desk
U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

SUBJECT: Service Water System Proposed Technical Specification Amendment

Transmitted herewith are the original and two (2) copies of an "Application for Amendment to the Operating License", sworn to on December 29, 1988. This Application requests an amendment to the Con Edison Indian Point Unit No. 2 Technical Specifications.

The specific proposed Technical Specification changes are set forth in Attachment I to this Application. For the designated essential service water pumps, under the proposed amendment the allowed out-of-service time for one pump would be increased from 8 hours to 12 hours, three pumps would be required to be operable when the reactor is above 350°F (as opposed to criticality as presently stated), and a 36 hour time period for attaining cold shutdown if the LCO cannot be satisfied would be established where no limit currently exists.

Another change is the inclusion of a Limiting Condition for Operation (LCO) for two service water pumps on the designated non-essential header, together with their associated piping and valves, to be operable when the reactor is above 350°F. Technical Specification 3.3.F would be revised in accordance with our commitment made in response to an observation from Safety System Functional Inspection 88-200 and fulfills the requirement of 10 CFR 50.36(c)(2).

Requirements for interconnection of the essential and non-essential headers would be relocated to a separate subsection.

A safety assessment, presented in Attachment II to this Application, provides the "No Significant Hazards Considerations" determination for the proposed amendment.

Pursuant to 10 CFR 170.12, a check in the amount of \$150.00 is enclosed as payment of the application fee for the review of these proposed changes to the Technical Specifications.

8901120254 881229
PDR ADOCK 05000247
P PNU

A001
1/1
w/check \$150
#E741061

Should you or your staff have any questions regarding this matter, please contact Mr. Jude G. Del Percio, Manager, Regulatory Affairs.

Very truly yours,



cc: Mr. William Russell
Regional Administrator - Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1498

Ms. Marylee M. Slosson, Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, NY 10511

Ms Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Plaza
Albany, NY 12223

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511