

Stephen B. Bram
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

March 9, 1990

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

SUBJECT: Corrections to Technical Specification Page 3.3-3

This letter is to request that page 3.3-3 of the Indian Point Unit No. 2 Technical Specifications be reissued to correct apparent administrative oversights concerning Amendments No. 144, 146 and 147. These three amendments were issued within a short time of each other and the changes to this page that were approved in the two earlier amendments were inadvertently omitted for each subsequent amendment. Accordingly, Amendment No. 146 did not incorporate the changes approved in Amendment No. 144, and Amendment No. 147 did not incorporate the changes approved in Amendments No. 144 and 146.

Amendment No. 144 changed the out of service time for the containment spray system in Paragraph B.2.c from 24 hours to 72 hours. Paragraph B.2.d was added in this amendment also. Amendment No. 146 deleted the requirements for the Boron Injection Tank flow path heat tracing from Paragraph A.2.e. Amendment No. 147 changed the sodium hydroxide concentration of the spray additive tank from 30% to 33% in Paragraph B.1.a.

Enclosed are two corrected versions of page 3.3-3, one for Amendment No. 146 and the other for Amendment No. 147. Please issue the corrected pages as soon as possible so that the amendment chronology is correctly documented and all controlled copies of the Indian Point Unit No. 2 Technical Specifications can be properly updated.

Should you or your staff have any questions regarding this matter, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

9003270349 900309
PDR ADDCK 05000247
P PDC

D

Very truly yours,



Aool
1/1

cc: Mr. William Russell
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Donald S. Brinkman, Senior Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
US Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511