

Stephen B. Bram  
Vice President

Consolidated Edison Company of New York, Inc.  
Indian Point Station  
Broadway & Bleakley Avenue  
Buchanan, NY 10511  
Telephone (914) 737-8116

September 26, 1990

Re: Indian Point Unit No. 2  
Docket No. 50-247

Document Control Desk  
US Nuclear Regulatory Commission  
Mail Station P1-137  
Washington, DC 20555

SUBJECT: Emergency Diesel Generator Proposed Technical Specification  
Amendment

Transmitted herewith are the original and two (2) copies of an "Application for Amendment to the Operating License", sworn to on September 26, 1990. This Application requests an amendment to the Con Edison, Indian Point Unit No. 2 Technical Specifications.

The specific proposed Technical Specification changes are set forth in Attachment I to this Application. The proposed changes would modify the Component Cooling System Technical Specification to reflect changes made to the power feeds for the Component Cooling Pumps, increase the Emergency Diesel Generator (EDG) short term rating, and increase the EDG fuel oil minimum storage requirements. The proposed changes would also clarify the text with respect to the EDG nameplate rating, the tanks designated to store the 7 day minimum EDG fuel oil inventory, and the 138/345 kv feeds at the Buchanan Substation.

A Safety Assessment, presented in Attachment II to this Application, provides the "No Significant Hazards Consideration" determination for the proposed amendment.

Should you or your staff have any questions, regarding this matter, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

Very truly yours,



Attachments

03120

9010100223 900926  
PDR ADOCK 05000247  
P PDC

A001  
'11

cc: Mr. Thomas T. Martin  
Regional Administrator - Region I  
US Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Donald S. Brinkman, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects I/II  
US Nuclear Regulatory Commission  
Mail Stop 14B-2  
Washington, DC 20555

Senior Resident Inspector  
US Nuclear Regulatory Commission  
PO Box 38  
Buchanan, NY 10511

Mayor, Village of Buchanan  
236 Tate Avenue  
Buchanan, NY 10511

Ms. Donna Ross  
Division of Policy Analysis and Planning  
New York State Energy Office  
Agency Building 2, Empire State Building  
Albany, NY 12223