

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)

CONSOLIDATED EDISON COMPANY)
OF NEW YORK, INC.)
(Indian Point Station)
Unit No. 2))

Docket No. 50-247


APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to 10 CFR 50.90 of the Regulations of the Nuclear Regulatory Commission (NRC), Consolidated Edison Company of New York, Inc. (Con Edison), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of that license. Specifically, we request that Technical Specifications 3.3.E, 3.7.A, 3.7.D, 4.6.A and 4.6.B, and Technical Specification Basis 3.7 and 4.6 be amended to reflect changes made to the power feeds for the Component Cooling Pumps, increase the Emergency Diesel Generator (EDG) fuel oil minimum required storage and the EDG short term rating and to clarify the text with respect to the EDG nameplate rating, the tanks designated to store the 7 day minimum EDG fuel oil inventory, and the 138/345 kv feeds at the Buchanan Substation.

The specific proposed Technical Specification revisions are set forth in Attachment I to this Application. A Safety Assessment for the proposed changes is set forth in Attachment II to this Application. This assessment concludes that the proposed changes do not represent a "Significant Hazards Consideration" as defined in 10 CFR 50.92(c).

As required by 10 CFR 50.91(b)(1), a copy of this application and our analysis concluding that the proposed changes do not constitute a "Significant Hazards Consideration" have been provided to the appropriate New York State Official designated to receive such amendments.

By:


Stephen B. Bram
Vice President
Nuclear Power

Subscribed and sworn to
before me this 26th day
of September, 1990.


Notary Public

KAREN L LANCASTER
Notary Public, State of New York
No. 60-4643659
Qualified in Westchester County
Term Expires 9/30/91