

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
CONSOLIDATED EDISON COMPANY) Docket No. 50-247
OF NEW YORK, INC.)
(Indian Point Station,)
Unit No. 2))


APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission ("NRC"), Consolidated Edison Company of New York, Inc. ("Con Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A of that license. Specifically, Con Edison requests that surveillance intervals for the Reactor Protection System (RPS) and Engineered Safety Features (ESF) analog channels be increased from monthly to quarterly and that routine analog channel testing in bypass mode be permitted.

The specific proposed Technical Specification revisions are set forth in Attachment A to this Application. A Safety Assessment of the proposed changes is set forth in Attachment B to this Application. This assessment demonstrates that the proposed changes do not represent a significant hazards consideration as defined in 10 CFR 50.92(c).

As required by 10 CFR 50.91(b)(1), a copy of this application and our analysis concluding that the proposed changes do not constitute a significant hazards consideration have been provided to the appropriate New York State official designated to receive such amendments.

By:



Stephen B. Bram
Vice Present

Subscribed and sworn to
before me this 31st day
of October, 1990.



Notary Public

ELIZABETH A. CASEY
Notary Public, State of New York
Qualified in Dutchess County
Reg # 4878094
Commission Expires Feb 9, 19 91