

Stephen B. Bram  
Vice President

Consolidated Edison Company of New York, Inc.  
Indian Point Station  
Broadway & Bleakley Avenue  
Buchanan, NY 10511  
Telephone (914) 737-8116

November 12, 1992

Re: Indian Point Unit No. 2  
Docket No. 50-247

Document Control Desk  
US Nuclear Regulatory Commission  
Mail Station P1-137  
Washington, DC 20555

SUBJECT: Proposed Amendment to Technical Specifications  
Regarding Snubber Visual Inspection Intervals

Consolidated Edison Company of New York, Inc. transmits herewith one (1) signed original and two (2) copies of the document entitled "Application for Amendment to Operating License" sworn to November 12, 1992. This application requests an amendment to the Indian Point Unit No. 2 Technical Specifications that would revise the schedule for visual inspection of snubbers in accordance with Generic Letter 90-09 "Alternative Requirements for Snubber Visual Inspection Intervals and Corrective Actions." The values in the proposed schedule were obtained by interpolation from the table provided in Generic Letter 90-09.

The snubber visual inspection schedule for the 1993 Refueling Outage would be affected by these revised Technical Specifications. Therefore, an expeditious review of this application by February 1, 1993 would be greatly appreciated.

Should you or your staff have any questions regarding this submittal, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

Very truly yours,



190063

9211190281 921112  
PDR ADOCK 05000247  
P PDR

ADD 1

Attachments

cc: Mr. Thomas T. Martin  
Regional Administrator - Region I  
US Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Francis J. Williams Jr., Project Manager  
Project Directorate I-1  
Division of Reactor Projects I/II  
US Nuclear Regulatory Commission  
Mail Stop 14B-2  
Washington, DC 20555

Senior Resident Inspector  
US Nuclear Regulatory Commission  
PO Box 38  
Buchanan, NY 10511

Mayor, Village of Buchanan  
236 Tate Avenue  
Buchanan, NY 10511

Ms. Donna Ross  
Division of Policy Analysis and Planning  
New York State Energy Office  
Agency Building 2, Empire State Building  
Albany, NY 12223