

John D. O'Toole
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 460-2533

April 23, 1982

Re: Indian Point Unit No. 2
Docket No. 50-247

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

ATTN: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing



Dear Mr. Varga:

We have completed our review of the Staff Safety Evaluation and Environmental Impact Appraisal forwarded with Amendment No. 75 to Facility Operating License No. DPR-26 and have found that two items require editorial correction. The corrected information is provided in Attachment A to this letter.

Should you or your staff have any questions, please contact us.

Very truly yours,

*William P. Bennett
for John D. O'Toole*

attach.

*Asst
5/11*

8205110339 820423
PDR ADOCK 05000247
P PDR

ATTACHMENT A

<u>Item</u>	<u>Correction</u>
1. Staff Safety Evaluation- Section 2.0.	The maximum storage capacity of 980 locations is provided by 12 racks with the modular cell units of each rack arranged in arrays of 8x8, 8x9, 8x10, 9x10 and 10x10. (Ref: Letter from J. O'Toole (Con Edison) to S. Varga (NRC) dated May 6, 1980).
2. Staff Environmental Impact Appraisal- Section 3.0.	There are presently 268 spent fuel assemblies stored in the spent fuel pool (Ref: Letter from J. O'Toole (Con Edison) to W. McDonald (NRC) dated April 15, 1981).