

John D. O'Toole
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 460-2533

December 7, 1984
Re: Indian Point Unit No. 2
Docket No. 50-247

Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing, NRR
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Varga:

This is in response to your letter of October 24, 1984 concerning our Appendix R exemption request regarding HVAC exhaust fans. Your letter contained stipulations on our alternate cooling method which are addressed below.

A portable exhaust fan is stored onsite and the alternate safe shutdown system procedure was revised to include instructions in the use of the portable cooling for the charging or RHR pump rooms and instructions to open the rollup door in the auxiliary feedpump room. This procedure is included in the operator training/retraining program.

If you have any questions on this matter, do not hesitate to call me.

Very truly yours,



cc: Office of Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, NY 10511

8412130204 841207
PDR ADDCK 05000247
F PDR

A006
1/0