

John D. O'Toole
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 460-2533

October 9, 1985

Re: Indian Point Unit No. 2
Docket No. 50-247

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

ATTN: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

Dear Mr. Varga:

Our letter, dated August 6, 1985, requested a revision to the Indian Point Unit No. 2 Technical Specifications for inclusion of a temporary closure plate in place of the containment equipment door during refueling. This letter is in response to a request made by your staff for additional information regarding the materials of construction and the pressure bearing capability of our proposed temporary closure plate. The design of the temporary closure plate is proposed to have a pressure bearing capability of 3 psi and will use carbon steel as the material of construction. If you or your staff have any additional questions, do not hesitate to call.

Very truly yours,



cc: Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, New York 10511

*Pool
10/10*

8510180039 851009
PDR ADCK 05000247
P PDR