

Murray Selman
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

January 27, 1987


Re: Indian Point Unit No. 2
Docket No. 50-247

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

This letter responds to a second request for additional information concerning our December 27, 1985 application to amend the Indian Point Unit No. 2 (IP-2) operating license to provide that the date upon which the unit operating license would expire would be 40 years from the date of issuance, September 28, 2013. The additional information verbally requested is included in Attachment A to this letter.

Please contact us if you have further questions concerning this submittal.

Very truly yours,



cc: Ms. Marylee M. Slosson, Project Manager
Project Directorate #3
Division of PWR Licensing A
U. S. Nuclear Regulatory Commission
Philips Building, 7920 Norfolk Avenue
Bethesda, MD. 20014

Office of Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, N. Y. 10511

Dr. Thomas E. Murley
Regional Administrator - Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

8702030189 870127
PDR ADOCK 05000247
P PDR

Aool
11

Attachment A

Additional Information to Support the
License Amendment Request dated December 27, 1985

Consolidated Edison Company of New York, Inc.
Indian Point Unit No. 2
Docket No. 50-247
January, 1987

Consolidated Edison of New York

Additional Information to Support the
License Amendment Request Dated December 27, 1985

1. Provide clarifying information on solid radioactive waste to compare annual generation with the FES.

Response

	<u>Solid Radioactive Waste</u>	
	<u>cubic meters</u>	<u>truck loads</u>
- Projected total for 1986	325	23
- Actual total for 1986	269	19
- Projected total for 1990	225	16

A review of the past several years of data for Indian Point Unit No. 2 (IP-2) indicates that there has been a steady decrease in the annual volume of solid radwaste. The 1986 volume is the lowest since Unit No. 2 began operation. We are more than meeting our projected goals and expect to further minimize the generation and volume of these solid wastes.

2. Provide information on extending the State Pollutant Discharge Elimination System (SPDES) permit.

Response

By law, our SPDES permit must be renewed every five years by making application to the New York State Department of Environmental Conservation. The current permit was issued on May 14, 1981 and expired on May 13, 1986. Con Edison timely applied for a SPDES renewal permit for IP-2 on January 17, 1986. Pursuant to New York State Law, State Administrative Procedure Act Section 401.2, an expired SPDES permit continues in force and effect while a new permit application is being processed. We expect that subsequent SPDES permits will be issued in 1992, 1997, 2002, etc.