

Murray Selman
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

October 30, 1987

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Steam Generator Inspection Program for
Indian Point Unit No. 2

By a letter dated July 20, 1987, Consolidated Edison submitted its proposed steam generator inspection program for the 1987 refueling outage at Indian Point Unit No. 2. Your letter dated October 6, 1987 approved this program for implementation. In that letter we were requested to confirm the following supplemental information, clarifications and corrections to our July 20, 1987 submittal:


- The inspection program will utilize state-of-the-art digital data analysis techniques (i.e., MIZ-18, DDA 4).
- The frequency selection as given in the July 20, 1987 submittal is incorrect. The actual frequency selection will be 10/200/400/600 KHz. The 600 KHz signal is mixed with the 200 KHz signal for copper suppression.
- Unplugged row 2 and row 3 tubes will be inspected from the hot leg side through the U-bend.
- The 100% tube sample to be inspected up to the first support plate will include both the hot and cold leg sides.
- The data analysis will be performed by two independent evaluators (both employed by the same company) as a QA measure.
- We do not plan to perform special inspections to address wall thinning in the tubesheet crevice area. Apart from denting, all indications found to date at Indian Point Unit No. 2 have been located above the tubesheet. It is believed that the indications are pitting although this has not been confirmed.
- No significant primary to secondary leakage has been observed since the last S/G inspection in 1986.

8711050144 871030
PDR ADOCK 05000247
PDR

A047
1/0

This letter confirms that our program will address the identified points.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Murray Selman". The signature is written in dark ink and is positioned to the right of the typed name "Murray Selman".

24.190.10.16.1

cc: Ms. Marylee M. Slosson
Project Directorate I-1
Division of Reactor Projects, I/II
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. William Russell
Regional Administrator - Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, NY 10511